

Day	pH	Alk	Phos	Other	Y/N
1	7.7				Y
2	7.6				Y
3	7.2				Y
4	7.7				Y
5	7.6				Y
6	7.7				Y
7	7.4				Y
8	7.5				Y
9	7.4				Y
10	7.1				Y
11	7.2	40 mg/L			Y
12	7.2				Y
13	7.1				Y
14	7.1				Y
15	7.6				Y
16	7.4				Y
17	7.6				Y
18	7.0				Y
19	7.4				Y
20	7.5				Y
21	6.5				Y
22	6.9				Y
23	7.5	60 mg/L			Y
24	7.3				Y
25	7.6				Y
26	7.7				Y
27	7.4				Y
28	7.5				Y
29	7.3				Y
30	6.9				Y
31	7.4				Y

<<Have

minimums
been met for
this day?

ENTRY POINT

PWS ID: 41

00966

System Name: City of Yachats

Entry Point: E. 2nd + Prospect

Sample Period: September 2025
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was
less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry
Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH
Alk (Alkalinity)
PO4 (Orthophosphate)
Other ()

Print Name: David Buckwald

Signature: David Buckwald

Date: 10-9-25

Send to DWP within 10 days after end of
sampling period

(No = N = Excursion) Total N's

0

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>