

Lead & Copper Rule Corrosion Control


Day	pH	Alk	Phos	Other	Y/N
1	7.0				y
2	7.1				y
3	7.5				y
4	7.8				y
5	7.4				y
6	7.2				y
7	7.0				y
8	7.0				y
9	7.4				y
10	7.3				y
11	7.6				y
12	7.9				y
13	7.7				y
14	7.3				y
15	7.3				y
16	7.3				y
17	7.6				y
18	7.7				y
19	7.8				y
20	7.2				y
21	7.0				y
22	7.0				y
23	7.1				y
24	7.0				y
25	7.3				y
26	7.1				y
27	7.1				y
28	7.5				y
29	7.4				y
30	7.2				y
31	7.1				y

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41

System Name: City of Yachats

Entry Point: Prospect E 2nd

Sample Period: April 2026 
Month/Year

Number of excursions* during this month: _____
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

Alk (Alkalinity)

PO4 (Orthophosphate)

Other (_____)

Print Name: Rick McClung

Signature: R. McClung

Date: 4/9/26

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's