



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.54	50			Y
2	7.63	49			Y
3	7.72	49			Y
4	7.65	48			Y
5	7.66	50			Y
6	7.79	51			Y
7	7.60	50			Y
8	7.64	51			Y
9	7.70	50			Y
10	7.62	51			Y
11	7.71	50			Y
12	7.64	50			Y
13	7.72	54			Y
14	7.68	53			Y
15	7.82	51			Y
16	7.80	57			Y
17	7.62	56			Y
18	7.64	56			Y
19	7.72	56			Y
20	7.70	58			Y
21	7.64	58			Y
22	7.66	55			Y
23	7.78	53			Y
24	7.68	55			Y
25	7.72	55			Y
26	7.61	56			Y
27	7.64	57			Y
28	7.69	59			Y
29	7.72	57			Y
30	7.80	62			Y

<< Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

System Name: City of Yamhill
 Entry Point: EP-A
 Sample Period: Apr-21
 Month / Year

Number of excursions* during this month:

(Count the number of days when any WQP was less then the minimum required)

Total excursions during the previous 5 months:

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State:

pH
 Alk (Alkalinity)
 PO4 (Orthophosphate)
 Sili (Silicate)

Print Name: Kyle Adams

Signature: *Kyle Adams*

Date: 5/8/2021

(NO=N=Excursions) Total N's

Send to DHS within 10 days after end of sampling period

DHS-Drinking Water Program, PO Box 14350, Portland, Or 97293-0350 Phone (503) 731-4381