



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.64	58			Y
2	7.68	58			Y
3	7.72	58			Y
4	7.59	56			Y
5	7.55	60			Y
6	7.60	60			Y
7	7.57	58			Y
8	7.61	58			Y
9	7.59	58			Y
10	7.64	58			Y
11	7.61	58			Y
12	7.60	57			Y
13	7.64	57			Y
14	7.62	57			Y
15	7.59	58			Y
16	7.63	57			Y
17	7.62	57			Y
18	7.71	58			Y
19	7.68	58			Y
20	7.66	60			Y
21	7.67	58			Y
22	7.62	58			Y
23	7.66	58			Y
24	7.60	59			Y
25	7.87	60			Y
26	7.67	59			Y
27	7.62	60			Y
28	7.65	59			Y
29	7.61	58			Y
30	7.61	57			Y
31	7.64	58			Y

<< Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 0 0 9 6 8

System Name: City of Yamhill

Entry Point: EP-A

Sample Period: Jul-21
Month / Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less then the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State:

pH	7.2	
Alk		(Alkalinity)
PO4		(Orthophosphate)
Sili		(Silicate)

Print Name: Darrel Lockard

Signature: *Darrel Lockard*

Date: 8/7/2021

(NO=N=Excursions) **Total N's** 0