



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

| Day | pH | Alk | Phos | Sili | Y/N |
|-----|------|-----|------|------|-----|
| 1 | 7.73 | 60 | | | Y |
| 2 | 7.70 | 58 | | | Y |
| 3 | 7.68 | 59 | | | Y |
| 4 | 7.73 | 59 | | | Y |
| 5 | 7.74 | 58 | | | Y |
| 6 | 7.74 | 60 | | | Y |
| 7 | 7.70 | 60 | | | Y |
| 8 | 7.72 | 60 | | | Y |
| 9 | 7.74 | 59 | | | Y |
| 10 | 7.75 | 59 | | | Y |
| 11 | 7.71 | 59 | | | Y |
| 12 | 7.74 | 60 | | | Y |
| 13 | 7.73 | 60 | | | Y |
| 14 | 7.72 | 60 | | | Y |
| 15 | 7.70 | 60 | | | Y |
| 16 | 7.68 | 59 | | | Y |
| 17 | 7.72 | 59 | | | Y |
| 18 | 7.70 | 60 | | | Y |
| 19 | 7.76 | 59 | | | Y |
| 20 | 7.73 | 59 | | | Y |
| 21 | 7.75 | 60 | | | Y |
| 22 | 7.70 | 60 | | | Y |
| 23 | 7.76 | 60 | | | Y |
| 24 | 7.79 | 60 | | | Y |
| 25 | 7.67 | 59 | | | Y |
| 26 | 7.70 | 62 | | | Y |
| 27 | 7.72 | 62 | | | Y |
| 28 | 7.76 | 60 | | | Y |
| 29 | 7.72 | 60 | | | Y |
| 30 | 7.74 | 60 | | | Y |

<< Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 0 0 9 6 8

System Name: City of Yamhill

Entry Point: EP-A

Sample Period: Sep-21
Month / Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less then the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State:

pH 7.2

Alk (Alkalinity)

PO4 (Orthophosphate)

Sili (Silicate)

Print Name: Darrel Lockard

Signature: *Darrel Lockard*

Date: 10/8/2021

(NO=N=Excursions) **Total N's** 0