



# Water Quality Parameter Monitoring Form

## Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.62	56			Y
2	7.66	56			Y
3	7.67	58			Y
4	7.64	58			Y
5	7.70	56			Y
6	7.66	55			Y
7	7.52	56			Y
8	7.53	56			Y
9	7.58	54			Y
10	7.60	54			Y
11	7.62	54			Y
12	7.67	54			Y
13	7.57	49			Y
14	7.60	46			Y
15	7.61	45			Y
16	7.56	44			Y
17	7.74	42			Y
18	7.59	46			Y
19	7.56	45			Y
20	7.62	44			Y
21	7.59	47			Y
22	7.65	40			Y
23	7.58	44			Y
24	7.57	45			Y
25	7.64	44			Y
26	7.68	44			Y
27	7.56	44			Y
28	7.60	43			Y
29	7.58	42			Y
30	7.75	44			Y

<< Have minimums been met for this day?

**ENTRY POINT**

PWS ID: 41 0 0 9 6 8

System Name: City of Yamhill

Entry Point: EP-A

Sample Period: Nov-21  
Month / Year

**Number of excursions\* during this month:** 0  
 (Count the number of days when any WQP was less then the minimum required)

**Total excursions during the previous 5 months:** 0  
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

**Minimum Water Quality Parameters as set by State:**

pH 7.2

Alk  (Alkalinity)

PO4  (Orthophosphate)

Sili  (Silicate)

**Print Name:** Darrel Lockard

**Signature:** *Darrel Lockard*

**Date:** 12/8/2021

(NO=N=Excursions) **Total N's** 0