



# Water Quality Parameter Monitoring Form

## Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.68	44			Y
2	7.62	44			Y
3	7.66	46			Y
4	7.72	46			Y
5	7.77	49			Y
6	7.59	46			Y
7	7.70	42			Y
8	7.68	44			Y
9	7.58	45			Y
10	7.62	44			Y
11	7.62	46			Y
12	7.68	44			Y
13	7.64	42			Y
14	7.70	40			Y
15	7.66	42			Y
16	7.71	40			Y
17	7.65	42			Y
18	7.75	42			Y
19	7.65	42			Y
20	7.68	42			Y
21	7.70	43			Y
22	7.68	42			Y
23	7.62	42			Y
24	7.60	41			Y
25	7.70	42			Y
26	7.84	42			Y
27	7.73	44			Y
28	7.68	44			Y
29	7.80	46			Y
30	7.76	44			Y
31	7.68	40			Y

<< Have minimums been met for this day?

**ENTRY POINT**

PWS ID: 41 0 0 9 6 8

System Name: City of Yamhill

Entry Point: EP-A

Sample Period: Jan-22  
Month / Year

**Number of excursions\* during this month:** 0  
 (Count the number of days when any WQP was less then the minimum required)

**Total excursions during the previous 5 months:** 0  
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

**Minimum Water Quality Parameters as set by State:**

pH 7.2

Alk  (Alkalinity)

PO4  (Orthophosphate)

Sili  (Silicate)

**Print Name:** Darrel Lockard

**Signature:** *Darrel Lockard*

**Date:** 2/8/2022

(NO=N=Excursions) **Total N's** 0