



# Water Quality Parameter Monitoring Form

## Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.76	56			Y
2	7.73	56			Y
3	7.68	56			Y
4	7.72	54			Y
5	7.68	54			Y
6	7.74	53			Y
7	7.78	52			Y
8	7.75	52			Y
9	7.72	43			Y
10	7.67	46			Y
11	7.70	42			Y
12	7.66	42			Y
13	7.62	42			Y
14	7.55	40			Y
15	7.60	40			Y
16	7.62	47			Y
17	7.70	46			Y
18	7.75	46			Y
19	7.72	46			Y
20	7.70	46			Y
21	7.68	44			Y
22	7.72	45			Y
23	7.66	46			Y
24	7.79	46			Y
25	7.70	46			Y
26	7.66	46			Y
27	7.60	45			Y
28	7.70	45			Y
29	7.74	44			Y
30	7.68	44			Y
31	7.70	44			Y

<< Have minimums been met for this day?

**ENTRY POINT**

PWS ID: 41 0 0 9 6 8

System Name: City of Yamhill

Entry Point: EP-A

Sample Period: Mar-22  
Month / Year

**Number of excursions\* during this month:** 0  
 (Count the number of days when any WQP was less then the minimum required)

**Total excursions during the previous 5 months:** 0  
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

**Minimum Water Quality Parameters as set by State:**

pH 7.2

Alk  (Alkalinity)

PO4  (Orthophosphate)

Sili  (Silicate)

**Print Name:** Darrel Lockard

**Signature:** *Darrel Lockard*

**Date:** 4/10/2022

(NO=N=Excursions) **Total N's** 0