



# Water Quality Parameter Monitoring Form

## Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.72	42			Y
2	7.66	42			Y
3	7.57	40			Y
4	7.79	44			Y
5	7.72	44			Y
6	7.66	44			Y
7	7.77	46			Y
8	7.72	46			Y
9	7.76	46			Y
10	7.70	46			Y
11	7.68	46			Y
12	7.70	44			Y
13	7.74	44			Y
14	7.66	46			Y
15	7.60	46			Y
16	7.64	46			Y
17	7.70	46			Y
18	7.60	46			Y
19	7.66	46			Y
20	7.80	44			Y
21	7.60	44			Y
22	7.66	44			Y
23	7.72	44			Y
24	7.68	42			Y
25	7.62	42			Y
26	7.82	46			Y
27	7.77	46			Y
28	7.74	46			Y
29	7.62	44			Y
30	7.58	44			Y
31	7.68	44			Y

<< Have minimums been met for this day?

<b>ENTRY POINT</b>	
PWS ID: 41	0   0   9   6   8
<b>System Name:</b>	<u>City of Yamhill</u>
<b>Entry Point:</b>	<u>EP-A</u>
<b>Sample Period</b>	<u>May-22</u> Month / Year

**Number of excursions\* during this month:** 0  
 (Count the number of days when any WQP was less then the minimum required)

**Total excursions during the previous 5 months:** 0  
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

<b>Minimum Water Quality Parameters as set by State:</b>	
pH	7.2
Alk	
PO4	
Sili	

(Alkalinity)  
(Orthophosphate)  
(Silicate)

**Print Name:** Darrel Lockard

**Signature:** *Darrel Lockard*

**Date:** 6/9/2022

(NO=N=Excursions) **Total N's** 0