



Water Quality Parameter Monitoring Form

**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Sili	Y/N
1	7.77	60			Y
2	7.72	60			Y
3	7.74	60			Y
4	7.78	60			Y
5	7.76	60			Y
6	7.77	60			Y
7	7.81	60			Y
8	7.74	60			Y
9	7.78	60			Y
10	7.80	60			Y
11	7.74	60			Y
12	7.78	60			Y
13	7.82	60			Y
14	7.77	60			Y
15	7.74	60			Y
16	7.80	60			Y
17	7.76	60			Y
18	7.78	60			Y
19	7.77	60			Y
20	7.76	60			Y
21	7.80	60			Y
22	7.72	60			Y
23	7.78	60			Y
24	7.82	60			Y
25	7.77	60			Y
26	7.76	60			Y
27	7.72	60			Y
28	7.80	60			Y
29	7.76	58			Y
30	7.72	58			Y
31	7.77	60			Y

<< Have minimums been met for this day?

**ENTRY POINT**

PWS ID: 41

System Name: City of Yamhill

Entry Point: EP-A

Sample Period: Oct-22  
Month / Year

Number of excursions\* during this month:   
 (Count the number of days when any WQP was less then the minimum required)

Total excursions during the previous 5 months:   
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

**Minimum Water Quality Parameters as set by State:**

pH

Alk  (Alkalinity)

PO4  (Orthophosphate)

Sili  (Silicate)

Print Name: Darrel Lockard

Signature: *Darrel Lockard*

Date: 11/9/2022

(NO=N=Excursions) Total N's

Send to DHS within 10 days after end of sampling period

DHS-Drinking Water Program, PO Box 14350, Portland, Or 97293-0350 Phone (503) 731-4381