



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.76	60			Y
2	7.74	60			Y
3	7.72	58			Y
4	7.77	58			Y
5	7.78	58			Y
6	7.75	56			Y
7	7.72	56			Y
8	7.76	56			Y
9	7.78	56			Y
10	7.78	54			Y
11	7.70	54			Y
12	7.72	54			Y
13	7.74	54			Y
14	7.70	52			Y
15	7.77	52			Y
16	7.78	50			Y
17	7.76	50			Y
18	7.72	50			Y
19	7.77	46			Y
20	7.72	46			Y
21	7.77	46			Y
22	7.76	46			Y
23	7.78	46			Y
24	7.72	44			Y
25	7.77	44			Y
26	7.73	44			Y
27	7.70	42			Y
28	7.72	42			Y
29	7.77	42			Y
30	7.76	42			Y
					N

<< Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

System Name: City of Yamhill

Entry Point: EP-A

Sample Period: Nov-22
Month / Year

Number of excursions* during this month:
 (Count the number of days when any WQP was less then the minimum required)

Total excursions during the previous 5 months:
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State:

pH

Alk (Alkalinity)

PO4 (Orthophosphate)

Sili (Silicate)

Print Name: Darrel Lockard

Signature: *Darrel Lockard*

(NO=N=Excursions) Total N's

Date: 12/10/2022