



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.72	40			Y
2	7.75	40			Y
3	7.68	40			Y
4	7.77	40			Y
5	7.72	40			Y
6	7.76	42			Y
7	7.74	42			Y
8	7.78	42			Y
9	7.77	42			Y
10	7.80	40			Y
11	7.84	40			Y
12	7.78	40			Y
13	7.75	40			Y
14	7.77	40			Y
15	7.70	40			Y
16	7.72	42			Y
17	7.74	42			Y
18	7.75	42			Y
19	7.73	42			Y
20	7.71	40			Y
21	7.77	40			Y
22	7.72	40			Y
23	7.76	40			Y
24	7.78	40			Y
25	7.74	40			Y
26	7.77	40			Y
27	7.72	40			Y
28	7.76	40			Y
29	7.78	40			Y
30	7.74	40			Y
31	7.70	40			Y

<< Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

System Name: City of Yamhill

Entry Point: EP-A

Sample Period: Jan-23
Month / Year

Number of excursions* during this month:
(Count the number of days when any WQP was less then the minimum required)

Total excursions during the previous 5 months:
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State:

pH

Alk (Alkalinity)

PO4 (Orthophosphate)

Sili (Silicate)

Print Name: Darrel Lockard

Signature: Darrel Lockard

Date: 2/10/2023

(NO=N=Excursions) Total N's