



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.70	44			Y
2	7.74	44			Y
3	7.72	44			Y
4	7.78	46			Y
5	7.87	46			Y
6	7.80	46			Y
7	7.86	50			Y
8	7.82	50			Y
9	7.79	48			Y
10	7.77	48			Y
11	7.80	48			Y
12	7.85	46			Y
13	7.87	46			Y
14	7.80	46			Y
15	7.84	46			Y
16	7.78	46			Y
17	7.77	46			Y
18	7.82	48			Y
19	7.80	48			Y
20	7.77	46			Y
21	7.74	46			Y
22	7.76	46			Y
23	7.72	46			Y
24	7.70	46			Y
25	7.76	48			Y
26	7.74	48			Y
27	7.76	48			Y
28	7.77	46			Y
29	7.80	46			Y
30	7.76	46			Y

<< Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

System Name: City of Yamhill
 Entry Point: EP-A
 Sample Period: Jun-23
 Month / Year

Number of excursions* during this month:

(Count the number of days when any WQP was less then the minimum required)

Total excursions during the previous 5 months:

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State:

pH
 Alk (Alkalinity)
 PO4 (Orthophosphate)
 Sili (Silicate)

Print Name: Darrel Lockard

Signature: _____

Date: 8/14/2023

(NO=N=Excursions) Total N's

Send to DHS within 10 days after end of sampling period

DHS-Drinking Water Program, PO Box 14350, Portland, Or 97293-0350 Phone (503) 731-4381