



Water Quality Parameter Monitoring Form

**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Sili	Y/N
1	7.78	52			Y
2	7.80	52			Y
3	7.76	52			Y
4	7.77	50			Y
5	7.82	51			Y
6	7.79	50			Y
7	7.80	50			Y
8	7.82	52			Y
9	7.80	52			Y
10	7.76	50			Y
11	7.73	52			Y
12	7.78	54			Y
13	7.80	54			Y
14	7.77	54			Y
15	7.74	52			Y
16	7.78	52			Y
17	7.80	52			Y
18	7.78	50			Y
19	7.82	50			Y
20	7.76	50			Y
21	7.77	50			Y
22	7.84	52			Y
23	7.81	52			Y
24	7.80	52			Y
25	7.86	50			Y
26	7.82	50			Y
27	7.77	50			Y
28	7.76	50			Y
29	7.78	50			Y
30	7.81	50			Y

<< Have minimums been met for this day?

**ENTRY POINT**

PWS ID: 41

System Name: City of Yamhill

Entry Point: EP-A

Sample Period: Sep-23  
Month / Year

Number of excursions\* during this month:   
 (Count the number of days when any WQP was less then the minimum required)

Total excursions during the previous 5 months:   
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

**Minimum Water Quality Parameters as set by State:**

pH

Alk  (Alkalinity)

PO4  (Orthophosphate)

Sili  (Silicate)

Print Name: Darrel Lockard

Signature: *Darrel Lockard*

Date: 10/10/2023

(NO=N=Excursions) Total N's