



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

| Day | pH | Alk | Phos | Sili | Y/N |
|-----|----|-----|------|------|-----|
|-----|----|-----|------|------|-----|

| | | | | | |
|----|------|----|--|--|---|
| 1 | 7.70 | 42 | | | Y |
| 2 | 7.74 | 42 | | | Y |
| 3 | 7.72 | 42 | | | Y |
| 4 | 7.77 | 40 | | | Y |
| 5 | 7.70 | 40 | | | Y |
| 6 | 7.66 | 40 | | | Y |
| 7 | 7.68 | 40 | | | Y |
| 8 | 7.70 | 40 | | | Y |
| 9 | 7.72 | 42 | | | Y |
| 10 | 7.72 | 42 | | | Y |
| 11 | 7.77 | 42 | | | Y |
| 12 | 7.79 | 42 | | | Y |
| 13 | 7.77 | 40 | | | Y |
| 14 | 7.74 | 40 | | | Y |
| 15 | 7.70 | 40 | | | Y |
| 16 | 7.69 | 40 | | | Y |
| 17 | 7.71 | 42 | | | Y |
| 18 | 7.75 | 42 | | | Y |
| 19 | 7.70 | 40 | | | Y |
| 20 | 7.72 | 40 | | | Y |
| 21 | 7.77 | 40 | | | Y |
| 22 | 7.72 | 40 | | | Y |
| 23 | 7.74 | 40 | | | Y |
| 24 | 7.68 | 40 | | | Y |
| 25 | 7.70 | 40 | | | Y |
| 26 | 7.70 | 40 | | | Y |
| 27 | 7.76 | 40 | | | Y |
| 28 | 7.77 | 40 | | | Y |
| 29 | 7.74 | 40 | | | Y |
| 30 | 7.72 | 40 | | | Y |
| 31 | 7.75 | 40 | | | Y |

<< Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

| | | | | |
|---|---|---|---|---|
| 0 | 0 | 9 | 6 | 8 |
|---|---|---|---|---|

System Name: City of Yamhill
 Entry Point: EP-A
 Sample Period: Dec-23
 Month / Year

Number of excursions* during this month:
 (Count the number of days when any WQP was less than minimum required)

Total excursions during the previous 5 months:
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State:

pH

| |
|-----|
| 7.2 |
|-----|

 Alk

| |
|--|
| |
|--|

 (Alkalinity)
 PO4

| |
|--|
| |
|--|

 (Orthophosphate)
 Sili

| |
|--|
| |
|--|

 (Silicate)

Print Name: Darrel Lockard

Signature: *Darrel Lockard*

(NO=N=Excursions) Total N's

| |
|---|
| 0 |
|---|

Date: 1/10/2024