



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.76	40			Y
2	7.75	40			Y
3	7.74	40			Y
4	7.77	40			Y
5	7.78	40			Y
6	7.75	40			Y
7	7.72	40			Y
8	7.76	40			Y
9	7.70	40			Y
10	7.72	40			Y
11	7.75	42			Y
12	7.74	40			Y
13	7.72	40			Y
14	7.72	40			Y
15	7.76	40			Y
16	7.77	40			Y
17	7.72	40			Y
18	7.76	40			Y
19	7.77	42			Y
20	7.80	40			Y
21	7.78	42			Y
22	7.74	42			Y
23	7.76	42			Y
24	7.72	42			Y
25	7.74	42			Y
26	7.76	42			Y
27	7.72	42			Y
28	7.77	42			Y
29	7.77	42			Y
30	7.75	42			Y

<< Have minimums been met for this day?

ENTRY POINT					
PWS ID: 41 0 0 9 6 8					
System Name: <u>City of Yamhill</u>					
Entry Point: <u>EP-A</u>					
Sample Period: <u>Apr-24</u>					
Month / Year					

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less then the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State:	
pH	7.2
Alk	
PO4	
Sili	

(Alkalinity)
(Orthophosphate)
(Silicate)

Print Name: DARREL LOCKARD

Signature: *Darrel Lockard*

Date: 5/7/24

(NO=N=Excursions) Total N's 0