



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.78	42			Y
2	7.74	42			Y
3	7.70	42			Y
4	7.72	42			Y
5	7.78	42			Y
6	7.77	42			Y
7	7.72	40			Y
8	7.70	40			Y
9	7.74	40			Y
10	7.77	40			Y
11	7.76	40			Y
12	7.72	40			Y
13	7.70	40			Y
14	7.74	40			Y
15	7.72	40			Y
16	7.78	38			Y
17	7.76	38			Y
18	7.78	38			Y
19	7.75	38			Y
20	7.70	40			Y
21	7.73	40			Y
22	7.76	40			Y
23	7.80	40			Y
24	7.77	40			Y
25	7.74	40			Y
26	7.76	40			Y
27	7.72	42			Y
28	7.77	42			Y
29	7.76	42			Y
30	7.80	42			Y
31	7.78	42			Y

<< Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

System Name: City of Yamhill
Entry Point: EP-A
Sample Period: May-24
 Month / Year

Number of excursions* during this month:

(Count the number of days when any WQP was less then the minimum required)

Total excursions during the previous 5 months:

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State:

pH
 Alk (Alkalinity)
 PO4 (Orthophosphate)
 Sili (Silicate)

Print Name: Darrel Lockard Cert#2853

Signature: *Darrel Lockard*

Date: 6/10/2024

(NO=N=Excursions) **Total N's**

Send to DHS within 10 days after end of sampling period

DHS-Drinking Water Program, PO Box 14350, Portland, Or 97293-0350 Phone (503) 731-4381