



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.77	50			Y
2	7.80	50			Y
3	7.85	50			Y
4	7.80	52			Y
5	7.77	52			Y
6	7.80	52			Y
7	7.78	52			Y
8	7.84	54			Y
9	7.80	54			Y
10	7.77	54			Y
11	7.76	54			Y
12	7.78	56			Y
13	7.80	56			Y
14	7.72	58			Y
15	7.74	58			Y
16	7.80	58			Y
17	7.82	58			Y
18	7.86	60			Y
19	7.82	60			Y
20	7.86	60			Y
21	7.88	60			Y
22	7.95	60			Y
23	7.98	62			Y
24	7.97	62			Y
25	7.94	62			Y
26	7.92	62			Y
27	7.88	62			Y
28	7.82	62			Y
29	7.89	62			Y
30	7.82	62			Y
31	7.86	62			Y

<< Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 0 0 9 6 8

System Name: City of Yamhill
 Entry Point: EP-A
 Sample Period: Jul-24
 Month / Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less then the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State:

pH 7.2
 Alk (Alkalinity)
 PO4 (Orthophosphate)
 Sili (Silicate)

Print Name: Darrel Lockard

Signature: Darrel Lockard

Date: 8/8/2024

(NO=N=Excursions) Total N's 0

Send to DHS within 10 days after end of sampling period

DHS-Drinking Water Program, PO Box 14350, Portland, Or 97293-0350 Phone (503) 731-4381