



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.82	62			Y
2					N
3					N
4					N
5					N
6					N
7					N
8	7.80	60			Y
9					N
10					N
11					N
12					N
13	7.77	60			Y
14					N
15					N
16					N
17					N
18					N
19	7.74	60			Y
20					N
21					N
22					N
23					N
24	7.82	60			Y
25					N
26					N
27					N
28					N
29	7.86	60			Y
30					N
31					N

<< Have minimums been met for this day?

Distribution

PWS ID: 41

System Name: City of Yamhill
 Entry Point: EP-A
 Sample Period: Aug-24
 Month / Year

Number of excursions* during this month:

(Count the number of days when any WQP was less then the minimum required)

Total excursions during the previous 5 months:

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State:

pH
 Alk (Alkalinity)
 PO4 (Orthophosphate)
 Sili (Silicate)

Print Name: Darrel Lockard

Signature: Darrel Lockard

Date: 9/4/2024

(NO=N=Excursions) Total N's

Send to DHS within 10 days after end of sampling period

DHS-Drinking Water Program, PO Box 14350, Portland, Or 97293-0350 Phone (503) 731-4381