



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.88	60			Y
2	7.74	62			Y
3	7.80	60			Y
4	7.76	62			Y
5	7.82	60			Y
6	7.72	60			Y
7	7.74	62			Y
8	7.70	62			Y
9	7.68	64			Y
10	7.80	64			Y
11	7.81	64			Y
12	7.77	64			Y
13	7.74	64			Y
14	7.78	64			Y
15	7.82	64			Y
16	7.76	62			Y
17	7.75	64			Y
18	7.80	64			Y
19	7.82	64			Y
20	7.77	64			Y
21	7.72	64			Y
22	7.76	62			Y
23	7.72	64			Y
24	7.76	64			Y
25	7.74	64			Y
26	7.77	64			Y
27	7.80	64			Y
28	7.77	64			Y
29	7.74	64			Y
30	7.77	64			Y
					N

<< Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 0 0 9 6 8

System Name: City of Yamhill
Entry Point: EP-A
Sample Period: Sep-24
Month / Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less then the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State:

pH	7.2	
Alk	55	(Alkalinity)
PO4		(Orthophosphate)
Sili		(Silicate)

Print Name: Darrel Lockard

Signature: *Darrel Lockard*

Date: 10/10/2024

(NO=N=Excursions) **Total N's** 0

Send to DHS within 10 days after end of sampling period

DHS-Drinking Water Program, PO Box 14350, Portland, Or 97293-0350 Phone (503) 731-4381