



# Water Quality Parameter Monitoring Form

## Lead & Copper Rule Corrosion Control

| Day | pH   | Alk | Phos | Sili | Y/N |
|-----|------|-----|------|------|-----|
| 1   | 7.74 | 64  |      |      | Y   |
| 2   | 7.76 | 64  |      |      | Y   |
| 3   | 7.75 | 64  |      |      | Y   |
| 4   | 7.70 | 64  |      |      | Y   |
| 5   | 7.78 | 64  |      |      | Y   |
| 6   | 7.70 | 64  |      |      | Y   |
| 7   | 7.66 | 66  |      |      | Y   |
| 8   | 7.72 | 66  |      |      | Y   |
| 9   | 7.70 | 64  |      |      | Y   |
| 10  | 7.77 | 66  |      |      | Y   |
| 11  | 7.74 | 66  |      |      | Y   |
| 12  | 7.76 | 66  |      |      | Y   |
| 13  | 7.82 | 64  |      |      | Y   |
| 14  | 7.77 | 64  |      |      | Y   |
| 15  | 7.80 | 66  |      |      | Y   |
| 16  | 7.78 | 66  |      |      | Y   |
| 17  | 7.80 | 66  |      |      | Y   |
| 18  | 7.77 | 64  |      |      | Y   |
| 19  | 7.74 | 64  |      |      | Y   |
| 20  | 7.70 | 64  |      |      | Y   |
| 21  | 7.76 | 66  |      |      | Y   |
| 22  | 7.74 | 66  |      |      | Y   |
| 23  | 7.80 | 64  |      |      | Y   |
| 24  | 7.82 | 64  |      |      | Y   |
| 25  | 7.76 | 64  |      |      | Y   |
| 26  | 7.71 | 66  |      |      | Y   |
| 27  | 7.75 | 66  |      |      | Y   |
| 28  | 7.70 | 66  |      |      | Y   |
| 29  | 7.74 | 66  |      |      | Y   |
| 30  | 7.77 | 64  |      |      | Y   |
| 31  | 7.75 | 66  |      |      | Y   |

<< Have minimums been met for this day?

### ENTRY POINT

PWS ID: 41 0 0 9 6 8

**System Name:** City of Yamhill  
**Entry Point:** EP-A  
**Sample Period:** Oct-24  
Month / Year

**Number of excursions\* during this month:** 0

(Count the number of days when any WQP was less then the minimum required)

**Total excursions during the previous 5 months:** 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

### Minimum Water Quality Parameters as set by State:

pH 7.2  
 Alk   (Alkalinity)  
 PO4   (Orthophosphate)  
 Sili   (Silicate)

**Print Name:** Darrel Lockard

**Signature:** *Darrel Lockard*

**Date:** 11/10/2024

(NO=N=Excursions) **Total N's** 0

Send to DHS within 10 days after end of sampling period

DHS-Drinking Water Program, PO Box 14350, Portland, Or 97293-0350 Phone (503) 731-4381