



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.78	66			Y
2					
3					
4	7.74	66			Y
5	7.76	66			Y
6	7.69	66			Y
7	7.72	66			Y
8	7.70	66			Y
9					
10	7.74	66			Y
11					
12	7.67	64			Y
13	7.69	64			Y
14	7.71	64			Y
15					
16	7.70	64			Y
17					
18	7.66	64			Y
19	7.70	64			Y
20	7.68	64			Y
21	7.67	64			Y
22					
23					
24					
25	7.70	62			Y
26	7.77				Y
27	7.80	62			Y
28	7.76	62			Y
29	7.74	64			Y
30					

<< Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

System Name: City of Yamhill
 Entry Point: EP-A
 Sample Period: Nov-24
 Month / Year

Number of excursions* during this month:

(Count the number of days when any WQP was less then the minimum required)

Total excursions during the previous 5 months:

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State:

pH
 Alk (Alkalinity)
 PO4 (Orthophosphate)
 Sili (Silicate)

Print Name: Darrel Lockard

Signature: *Darrel Lockard*

Date: 12/10/2024

(NO=N=Excursions) Total N's

Send to DHS within 10 days after end of sampling period

DHS-Drinking Water Program, PO Box 14350, Portland, Or 97293-0350 Phone (503) 731-4381