



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.77	62			Y
2	7.72	62			Y
3	7.80	60			Y
4					
5					
6	7.74	62			Y
7					
8	7.70	60			Y
9	7.73	58			Y
10	7.78	60			Y
11					
12					
13					
14	7.74	60			Y
15					
16	7.72	60			Y
17					
18	7.76	58			Y
19	7.74	58			Y
20					
21	7.80	60			Y
22					
23					
24	7.77	60			Y
25					
26	7.71	58			Y
27					
28					
29	7.68	58			Y
30					
31	7.74	60			Y

<< Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

System Name: City of Yamhill

Entry Point: EP-A

Sample Period: Jan-25
Month / Year

Number of excursions* during this month:

(Count the number of days when any WQP was less than minimum required)

Total excursions during the previous 5 months:

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State:

pH
Alk (Alkalinity)
PO4 (Orthophosphate)
Sili (Silicate)

Print Name: Darrel Lockard

Signature: Darrel Lockard

Date: 1/10/2025

(NO=N=Excursions) Total N's

Send to DHS within 10 days after end of sampling period