

Day	pH	Alk	Phos	Sili	Y/N
1	7.77	60			Y
2	7.74	60			Y
3	7.68	60			Y
4	7.76	60			Y
5					
6					
7	7.77	60			Y
8	7.74	60			Y
9	7.72	60			Y
10	7.75	58			Y
11	7.80	58			Y
12					
13					
14	7.79	60			Y
15	7.77	58			Y
16	7.82	60			Y
17	7.83	60			Y
18					
19					
20					
21	7.78	60			Y
22	7.79	60			Y
23	7.78	60			Y
24	7.80	60			Y
25	7.79	60			Y
26					
27					
28	7.80	62			Y
29	7.82	62			Y
30	7.77	62			Y

<< Have minimums been met for this day?

System Name:
Entry Point:
Sample Period:

ENTRY POINT
PWS ID: 41 0 0 9 6 8

City of Yamhill

EP-A

Apr-25

Month / Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality
Parameters as set by State:

pH 7.2
Alk 55 (Alkalinity)
PO4 (Orthophosphate)
Sili (Silicate)

Print Name:

Darrel Lockard

Signature:

Darrel Lockard

Date:

5/8/2025

(NO=N=Excursions) Total N's 0

Send to DHS within 10 days after end of sampling period
DHS-Drinking Water Program, PO Box 14350, Portland, Or 97293-0350 Phone (503) 731-4381