

Day	pH	Alk	Phos	Sili	Y/N
1	7.85	64			Y
2	7.83	64			Y
3					
4					
5	7.83	64			Y
6	7.84	64			Y
7	7.81	64			Y
8	7.83	64			Y
9	7.82	66			Y
10					
11					
12	7.75	62			Y
13	7.78	64			Y
14	7.83	66			Y
15	7.85	66			Y
16	7.84	66			Y
17					
18					
19	7.81	62			Y
20	7.82	62			Y
21	7.80	64			Y
22	7.81	62			Y
23	7.78	62			Y
24					
25					
26					
27	7.77	62			Y
28	7.80	64			Y
29	7.76	64			Y
30	7.79	64			Y
31					

<< Have minimums been met for this day?

System Name:
Entry Point:
Sample Period:

ENTRY POINT						
PWS ID:	41	0	0	9	6	8
City of Yamhill						
EP-A						
May-25						
Month / Year						

(Count the number of days when any WQP was less than the minimum required)

Number of excursions* during this month: 0

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only	
Minimum Water Quality	
Parameters as set by State:	
pH	7.2
Alk	55 (Alkalinity)
PO4	(Orthophosphate)
Sili	(Silicate)

Print Name: Darrel Lockard
Signature: *Darrel Lockard*

Date: 6/9/2025

(NO=N=Excursions) Total N's 0