



Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	SiO ₂	Y/N
1	7.80	84			Y
2	7.78	84			Y
3	7.77	84			Y
4	7.80	84			Y
5	7.78	84			Y
6	7.79	88			Y
7	7.77	88			Y
8	7.79	88			Y
9	7.77	88			Y
10	7.79	88			Y
11	7.82	88			Y
12	7.81	88			Y
13	7.79	88			Y
14	7.78	88			Y
15	7.78	88			Y
16	7.77	88			Y
17	7.77	88			Y
18	7.72	88			Y
19	7.78	88			Y
20	7.77	88			Y
21	7.75	88			Y
22	7.70	88			Y
23	7.74	88			Y
24	7.77	88			Y
25	7.78	88			Y
26	7.78	88			Y
27	7.78	88			Y
28	7.78	88			Y
29	7.78	88			Y
30	7.78	88			Y

Have minimums been met for this day?

System Name:
Entry Point:
Sample Period:

PWS ID:

41 0 0 9 6 8

ENTRY POINT

City of Yamhill

EP-A

Month / Year

Jun 26

(Count the number of days when any WQP was less than the minimum required)

Number of excursions* during this month: 8

Total excursions during the previous 6 months: 0

(Over 8 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality
Parameters as set by State:

pH 7.2
Alk 85
PO₄ (Orthophosphate)
SiO₂ (Silicate)

Print Name:

Daniel Lockard

Signature:

Daniel Lockard

Date:

7/10/2025

(NO=N=Excursions) Total N's 0

Send to DHS within 10 days after end of sampling period
DHS-Drinking Water Program, PO Box 14350, Portland, Or 97293-0350 Phone (503) 731-4361