



Day	pH	Alk	Phos	Sili	Y/N
1	7.80	68			Y
2					
3					
4	7.78	68			Y
5	7.77	68			Y
6	7.76	66			Y
7	7.82	64			Y
8					
9					
10	7.82	68			Y
11	7.80	68			Y
12	7.80	68			Y
13	7.77	68			Y
14	7.78	68			Y
15	7.85	66			Y
16					
17					
18	7.80	62			Y
19	7.82	62			Y
20	7.80	62			Y
21	7.83	64			Y
22	7.82	66			Y
23					
24					
25	7.81	66			Y
26	7.79	66			Y
27	7.80	66			Y
28	7.82	68			Y
29	7.83	68			Y
30					
31					

(NO=N=Excursions) Total N's 0

<< Have minimums been met for this day?

System Name:
Entry Point:
Sample Period:

ENTRY POINT						
PWS ID:	41	0	0	9	6	8
City of Yamhill						
EP-A						
Aug-25						
Month / Year						

(Count the number of days when any WQP was less then the minimum required)

Number of excursions* during this month: 0

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only	
Minimum Water Quality	
Parameters as set by State:	
pH	7.2
Alk	55 (Alkalinity)
PO4	(Orthophosphate)
Sili	(Silicate)

Print Name:
Signature:

Darrel Lockard

Date: 9/10/2025

Send to DHS within 10 days after end of sampling period
DHS-Drinking Water Program, PO Box 14350, Portland, Or 97293-0350 Phone (503) 731-4381