

Day	pH	Alk	Phos	Sili	Y/N
1	7.86	63			y
2					
3	7.83	64			y
4					
5					
6	7.85	66			y
7					
8	7.84	68			y
9					
10	7.84	68			y
11					
12					
13	7.85	66			y
14					
15					
16	7.86	68			y
17	7.83	68			y
18					
19					
20	7.84	66			y
21					
22	7.78	64			y
23					
24	7.76	64			y
25					
26					
27	7.74	62			y
28					
29	7.72	64			y
30					
31	7.77	66			y

(NO=N=Excursions) Total N's

<< Have minimums been met for this day?

ENTRY POINT						
PWS ID:	41	0	0	9	6	8
System Name:	City of Yamhill					
Entry Point:	EP-A					
Sample Period:	Oct-25					
Month / Year						

Number of excursions* during this month:

(Count the number of days when any WQP was less then the minimum required)

Total excursions during the previous 5 months:

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only	
Minimum Water Quality	
Parameters as set by State:	
pH	7.2
Alk	
PO4	
Sili	

Darrel Lockard

Print Name:

Signature:

Date: 11/10/2025

Send to DHS within 10 days after end of sampling period
 DHS-Drinking Water Program, PO Box 14350, Portland, Or 97293-0350 Phone (503) 731-4381