



Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1					
2					
3	7.70	64			Y
4					
5	7.73	64			Y
6					
7					
8					
9	7.83	58			Y
10					
11	7.71	56			Y
12					
13					
14					
15					
16					
17	7.77	54			Y
18					
19	7.76	54			Y
20					
21					
22					
23	7.76	52			Y
24					
25	7.75	52			Y
26					
27					
28	7.79	54			Y
29					
30					

(NO=N=Excursions) Total N's

<< Have minimums been met for this day?

ENTRY POINT						
PWS ID:	41	0	0	9	6	8
System Name:	City of Yamhill					
Entry Point:	EP-A					
Sample Period:	Nov-25					
Month / Year						

Number of excursions* during this month:

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months:

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only	
Minimum Water Quality	
Parameters as set by State:	
pH	7.2
Alk	(Alkalinity)
PO4	(Orthophosphate)
Sili	(Silicate)

Print Name:

Signature:

Date:

Send to DHS within 10 days after end of sampling period
DHS-Drinking Water Program, PO Box 14350, Portland, Or 97293-0350 Phone (503) 731-4381