



Lead & Copper Rule Corrosion Control

| Day | pH | Alk | Phos | Sili | Y/N |
|-----|------|-----|------|------|-----|
| 1 | 7.80 | 56 | | | Y |
| 2 | | | | | |
| 3 | | | | | |
| 4 | 7.72 | 56 | | | Y |
| 5 | | | | | |
| 6 | | | | | |
| 7 | | | | | |
| 8 | 7.71 | 58 | | | Y |
| 9 | | | | | |
| 10 | 7.78 | 58 | | | Y |
| 11 | | | | | |
| 12 | 7.80 | 56 | | | Y |
| 13 | | | | | |
| 14 | | | | | |
| 15 | 7.70 | 57 | | | Y |
| 16 | 7.70 | 58 | | | Y |
| 17 | | | | | |
| 18 | | | | | |
| 19 | | | | | |
| 20 | | | | | |
| 21 | | | | | |
| 22 | 7.76 | 56 | | | Y |
| 23 | | | | | |
| 24 | | | | | |
| 25 | 7.71 | 58 | | | Y |
| 26 | | | | | |
| 27 | | | | | |
| 28 | | | | | |
| 29 | 7.76 | 57 | | | Y |
| 30 | | | | | |
| 31 | | | | | |

<< Have minimums been met for this day?

(NO=N=Excursions) Total N's

| ENTRY POINT | | | | | | |
|----------------|-----------------|--------------------------------|--------------------------------|--------------------------------|--------------------------------|--------------------------------|
| PWS ID: | 41 | <input type="text" value="0"/> | <input type="text" value="0"/> | <input type="text" value="9"/> | <input type="text" value="6"/> | <input type="text" value="8"/> |
| System Name: | City of Yamhill | | | | | |
| Entry Point: | EP-A | | | | | |
| Sample Period: | Dec-25 | | | | | |
| | Month / Year | | | | | |

Number of excursions* during this month:

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months:

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

| Minimum Water Quality Parameters as set by State: | |
|---|--|
| pH | <input type="text" value="7.2"/> |
| Alk | <input type="text" value="55"/> (Alkalinity) |
| PO4 | <input type="text"/> (Orthophosphate) |
| Sil | <input type="text"/> (Silicate) |

Print Name: Darrel Lockard

Signature: *Darrel Lockard*

Date: 1/9/2026