oregon department of human services

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1					
2	7.83	57			Y
3					
4					
5	7.86	58			Y
6					
7					
8					
9	7.80	58			Y
10					
11					
12	7.91	58			Y
13					
14					
15					
16	7.79	57			Y
17					
18	7.81	59			Y
19					
20					
21					
22					
23					
24	7.76	57			Y
25					
26	7.93	59			Y
27					
28					

<< Have minimums been met for this day?

(NO=N=Excursions) **Total N's** 0

ENTRY POINT

PWS ID: 41 0 0 9 6 8

System Name: City of Yamhill

Entry Point: EP-A

Sample Period: Feb-26

Month / Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less then the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State:

pH	7.2	
Alk	55	(Alikalinity)
PO4		(Orthophosphate)
Sili		(Silicate)

Print Name: Darrel Lockard

Signature: Darrel Lockard

Date: 3/10/2026

Send to DHS within 10 days after end of sampling period

DHS-Drinking Water Program, PO Box 14350, Portland, Or 97293-0350 Phone (503) 731-4381