

| Day | pH   | Alk | Phos | Sili | Y/N |
|-----|------|-----|------|------|-----|
| 1   | 7.70 | 62  |      |      | Y   |
| 2   | 7.74 | 62  |      |      | Y   |
| 3   |      |     |      |      |     |
| 4   |      |     |      |      |     |
| 5   |      |     |      |      |     |
| 6   |      |     |      |      |     |
| 7   |      |     |      |      |     |
| 8   | 7.76 | 64  |      |      | Y   |
| 9   |      |     |      |      |     |
| 10  | 7.75 | 64  |      |      | Y   |
| 11  |      |     |      |      |     |
| 12  |      |     |      |      |     |
| 13  |      |     |      |      |     |
| 14  |      |     |      |      |     |
| 15  | 7.72 | 62  |      |      | Y   |
| 16  |      |     |      |      |     |
| 17  |      |     |      |      |     |
| 18  |      |     |      |      |     |
| 19  |      |     |      |      |     |
| 20  |      |     |      |      |     |
| 21  |      |     |      |      |     |
| 22  | 7.78 | 64  |      |      | Y   |
| 23  |      |     |      |      |     |
| 24  |      |     |      |      |     |
| 25  |      |     |      |      |     |
| 26  |      |     |      |      |     |
| 27  |      |     |      |      |     |
| 28  |      |     |      |      |     |
| 29  | 7.77 | 62  |      |      | Y   |
| 30  |      |     |      |      |     |

<< Have minimums been met for this day?

Distribution

PWS ID: 41 0 0 9 6 8

System Name:

City of Yamhill

Entry Point:

Distribution

Sample Period:

Sep-25

Month / Year

Number of excursions\* during this month: 0

(Count the number of days when any WQP was less then the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality  
Parameters as set by State:

pH 7.2  
Alk 55 (Alkalinity)  
PO4 (Orthophosphate)  
Sili (Silicate)

Print Name:

Darrel Lockard

Signature:

*Darrel Lockard*

Date:

10/10/2025

(NO=N=Excursions) Total N's 0

Send to DHS within 10 days after end of sampling period

DHS-Drinking Water Program, PO Box 14350, Portland, Or 97293-0350 Phone (503) 731-4381