

Water Quality Parameter Monitoring Form - EP-A and Distribution

**Lead & Copper Rule Corrosion Control**


**PWS Name/ID:** Neskowin Reg Water Dist - 4100970  
**Sample Period (Month/Year):** January-21  
**Required Sample Frequency:** Ph Every Day  
**Required Sample Frequency:** Alaklinity 2 Samples Per Month

Day	Sample Location	pH	Alk	PO4	Other	yes/no
1/1/2021	1st User for PH and EP-A for Alkalinity	7.5				Yes
1/2/2021	1st User for PH and EP-A for Alkalinity	7.6				Yes
1/3/2021	1st User for PH and EP-A for Alkalinity	7.6				Yes
1/4/2021	1st User for PH and EP-A for Alkalinity	7.2				Yes
1/5/2021	1st User for PH and EP-A for Alkalinity	7.5	28.0			Yes
1/6/2021	1st User for PH and EP-A for Alkalinity	7.5				Yes
1/7/2021	1st User for PH and EP-A for Alkalinity	7.5				Yes
1/8/2021	1st User for PH and EP-A for Alkalinity	7.5				Yes
1/9/2021	1st User for PH and EP-A for Alkalinity	7.6				Yes
1/10/2021	1st User for PH and EP-A for Alkalinity	7.6				Yes
1/11/2021	1st User for PH and EP-A for Alkalinity	7.5				Yes
1/12/2021	1st User for PH and EP-A for Alkalinity	7.6	35.0			Yes
1/13/2021	1st User for PH and EP-A for Alkalinity	7.6				Yes
1/14/2021	1st User for PH and EP-A for Alkalinity	7.6				Yes
1/15/2021	1st User for PH and EP-A for Alkalinity	7.4				Yes
1/16/2021	1st User for PH and EP-A for Alkalinity	7.4				Yes
1/17/2021	1st User for PH and EP-A for Alkalinity	7.5				Yes
1/18/2021	1st User for PH and EP-A for Alkalinity	7.5				Yes
1/19/2021	1st User for PH and EP-A for Alkalinity	7.5	37.0			Yes
1/20/2021	1st User for PH and EP-A for Alkalinity	7.7				Yes
1/21/2021	1st User for PH and EP-A for Alkalinity	7.7				Yes
1/22/2021	1st User for PH and EP-A for Alkalinity	7.6				Yes
1/23/2021	1st User for PH and EP-A for Alkalinity	7.7				Yes
1/24/2021	1st User for PH and EP-A for Alkalinity	7.7				Yes
1/25/2021	1st User for PH and EP-A for Alkalinity	7.7	38.0			Yes
1/26/2021	1st User for PH and EP-A for Alkalinity	7.8				Yes
1/27/2021	1st User for PH and EP-A for Alkalinity	7.6				Yes
1/28/2021	1st User for PH and EP-A for Alkalinity	7.9				Yes
1/29/2021	1st User for PH and EP-A for Alkalinity	7.9				Yes
1/30/2021	1st User for PH and EP-A for Alkalinity	8.0				Yes
1/31/2021	1st User for PH and EP-A for Alkalinity	7.7				Yes

Total number of excursions for PH during this monitoring period = 0  
 Total number of excursions for Alkalinity during this monitoring period = 0

Send to [dwp.dmce@state.or.us](mailto:dwp.dmce@state.or.us) within 10 days after end of sampling period

For OHA use only:	
Minimum Water Quality Parameters as set by: DHS	
pH	7.2
Alk	23

Signature:   
 Print Name: Troy N. Trute  
 Date: 2/2/2021