

Water Quality Parameter Monitoring Form - EP-A and Distribution

Lead & Copper Rule Corrosion Control


PWS Name/ID: Neskowin Reg Water Dist - 4100970
Sample Period (Month/Year): February-21
Required Sample Frequency: Ph Every Day
Required Sample Frequency: Alaklinity 2 Samples Per Month

Day	Sample Location	pH	Alk	PO4	Other	yes/no
2/1/2021	1st User for PH and EP-A for Alkalinity	7.7	40.0			Yes
2/2/2021	1st User for PH and EP-A for Alkalinity	7.9	39.0			Yes
2/3/2021	1st User for PH and EP-A for Alkalinity	7.9	41.0			Yes
2/4/2021	1st User for PH and EP-A for Alkalinity	7.9	38.0			Yes
2/5/2021	1st User for PH and EP-A for Alkalinity	7.8	44.0			Yes
2/6/2021	1st User for PH and EP-A for Alkalinity	7.8				Yes
2/7/2021	1st User for PH and EP-A for Alkalinity	7.8				Yes
2/8/2021	1st User for PH and EP-A for Alkalinity	7.8	46.0			Yes
2/9/2021	1st User for PH and EP-A for Alkalinity	7.7	44.0			Yes
2/10/2021	1st User for PH and EP-A for Alkalinity	7.8	44.0			Yes
2/11/2021	1st User for PH and EP-A for Alkalinity	7.7	39.0			Yes
2/12/2021	1st User for PH and EP-A for Alkalinity	7.7	39.0			Yes
2/13/2021	1st User for PH and EP-A for Alkalinity	7.8				Yes
2/14/2021	1st User for PH and EP-A for Alkalinity	7.8				Yes
2/15/2021	1st User for PH and EP-A for Alkalinity	7.8	40.0			Yes
2/16/2021	1st User for PH and EP-A for Alkalinity	7.8	40.0			Yes
2/17/2021	1st User for PH and EP-A for Alkalinity	7.7	44.0			Yes
2/18/2021	1st User for PH and EP-A for Alkalinity	7.8	46.0			Yes
2/19/2021	1st User for PH and EP-A for Alkalinity	7.9	44.0			Yes
2/20/2021	1st User for PH and EP-A for Alkalinity	7.8				Yes
2/21/2021	1st User for PH and EP-A for Alkalinity	7.8				Yes
2/22/2021	1st User for PH and EP-A for Alkalinity	7.7	40.0			Yes
2/23/2021	1st User for PH and EP-A for Alkalinity	7.8	40.0			Yes
2/24/2021	1st User for PH and EP-A for Alkalinity	7.6	44.0			Yes
2/25/2021	1st User for PH and EP-A for Alkalinity	7.7	39.0			Yes
2/26/2021	1st User for PH and EP-A for Alkalinity	7.6	38.0			Yes
2/27/2021	1st User for PH and EP-A for Alkalinity	7.7				Yes
2/28/2021	1st User for PH and EP-A for Alkalinity	7.7				Yes

Total number of excursions for PH during this monitoring period = 0
 Total number of excursions for Alkalinity during this monitoring period = 0

Send to dwp.dmce@state.or.us within 10 days after end of sampling period

For OHA use only:	
Minimum Water Quality Parameters as set by: DHS	
pH	7.2
Alk	23

Signature: 
 Print Name: Troy N. Trute
 Date: 3/8/2021