

Water Quality Parameter Monitoring Form - EP-A and Distribution

**Lead & Copper Rule Corrosion Control**


**PWS Name/ID:** Neskowin Reg Water Dist - 4100970  
**Sample Period (Month/Year):** June-21  
**Required Sample Frequency:** Ph Every Day  
**Required Sample Frequency:** Alaklinity 2 Samples Per Month

Day	Sample Location	pH	Alk	PO4	Other	yes/no
6/1/2021	1st User for PH and EP-A for Alkalinity	8.0	28.4			Yes
6/2/2021	1st User for PH and EP-A for Alkalinity	7.8	28.3			Yes
6/3/2021	1st User for PH and EP-A for Alkalinity	7.8	26.8			Yes
6/4/2021	1st User for PH and EP-A for Alkalinity	7.7	26.5			Yes
6/5/2021	1st User for PH and EP-A for Alkalinity	7.9				Yes
6/6/2021	1st User for PH and EP-A for Alkalinity	7.8				Yes
6/7/2021	1st User for PH and EP-A for Alkalinity	7.7	28.9			Yes
6/8/2021	1st User for PH and EP-A for Alkalinity	7.8	24.5			Yes
6/9/2021	1st User for PH and EP-A for Alkalinity	7.7	24.8			Yes
6/10/2021	1st User for PH and EP-A for Alkalinity	7.7	25.6			Yes
6/11/2021	1st User for PH and EP-A for Alkalinity	7.7	25.4			Yes
6/12/2021	1st User for PH and EP-A for Alkalinity	7.8				Yes
6/13/2021	1st User for PH and EP-A for Alkalinity	7.7				Yes
6/14/2021	1st User for PH and EP-A for Alkalinity	7.8	28.1			Yes
6/15/2021	1st User for PH and EP-A for Alkalinity	7.8	27.8			Yes
6/16/2021	1st User for PH and EP-A for Alkalinity	7.7	27.5			Yes
6/17/2021	1st User for PH and EP-A for Alkalinity	7.8	28.0			Yes
6/18/2021	1st User for PH and EP-A for Alkalinity	7.8	26.3			Yes
6/19/2021	1st User for PH and EP-A for Alkalinity	7.9				Yes
6/20/2021	1st User for PH and EP-A for Alkalinity	7.9				Yes
6/21/2021	1st User for PH and EP-A for Alkalinity	7.8	24.9			Yes
6/22/2021	1st User for PH and EP-A for Alkalinity	7.9	25.5			Yes
6/23/2021	1st User for PH and EP-A for Alkalinity	7.8	25.6			Yes
6/24/2021	1st User for PH and EP-A for Alkalinity	7.7	26.3			Yes
6/25/2021	1st User for PH and EP-A for Alkalinity	7.7	26.8			Yes
6/26/2021	1st User for PH and EP-A for Alkalinity	8.2				Yes
6/27/2021	1st User for PH and EP-A for Alkalinity	7.9				Yes
6/28/2021	1st User for PH and EP-A for Alkalinity	7.8	28.4			Yes
6/29/2021	1st User for PH and EP-A for Alkalinity	7.9	28.0			Yes
6/30/2021	1st User for PH and EP-A for Alkalinity	7.8	28.2			Yes

Total number of excursions for PH during this monitoring period = 0  
 Total number of excursions for Alkalinity during this monitoring period = 0

Send to [dwp.dmce@state.or.us](mailto:dwp.dmce@state.or.us) within 10 days after end of sampling period

For OHA use only:	
Minimum Water Quality Parameters as set by: DHS	
pH	7.2
Alk	23

Signature:   
 Print Name: Troy N. Trute  
 Date: 7/7/2021