

Water Quality Parameter Monitoring Form - EP-A and Distribution

Lead & Copper Rule Corrosion Control


PWS Name/ID: Neskowin Reg Water Dist - 4100970
Sample Period (Month/Year): October-21
Required Sample Frequency: Ph Every Day
Required Sample Frequency: Alaklinity 2 Samples Per Month

Day	Sample Location	pH	Alk	PO4	Other	yes/no
10/1/2021	1st User for PH and EP-A for Alkalinity	7.2	29.0			Yes
10/2/2021	1st User for PH and EP-A for Alkalinity	7.6				Yes
10/3/2021	1st User for PH and EP-A for Alkalinity	7.5				Yes
10/4/2021	1st User for PH and EP-A for Alkalinity	7.2	28.5			Yes
10/5/2021	1st User for PH and EP-A for Alkalinity	7.8	26.0			Yes
10/6/2021	1st User for PH and EP-A for Alkalinity	7.8	25.6			Yes
10/7/2021	1st User for PH and EP-A for Alkalinity	7.8	26.4			Yes
10/8/2021	1st User for PH and EP-A for Alkalinity	7.7	27.2			Yes
10/9/2021	1st User for PH and EP-A for Alkalinity	7.6				Yes
10/10/2021	1st User for PH and EP-A for Alkalinity	7.6				Yes
10/11/2021	1st User for PH and EP-A for Alkalinity	8.0	30.0			Yes
10/12/2021	1st User for PH and EP-A for Alkalinity	8.0	25.8			Yes
10/13/2021	1st User for PH and EP-A for Alkalinity	8.0	26.4			Yes
10/14/2021	1st User for PH and EP-A for Alkalinity	8.0	26.2			Yes
10/15/2021	1st User for PH and EP-A for Alkalinity	7.8	27.3			Yes
10/16/2021	1st User for PH and EP-A for Alkalinity	7.8				Yes
10/17/2021	1st User for PH and EP-A for Alkalinity	7.8				Yes
10/18/2021	1st User for PH and EP-A for Alkalinity	7.8	29.8			Yes
10/19/2021	1st User for PH and EP-A for Alkalinity	7.7	28.5			Yes
10/20/2021	1st User for PH and EP-A for Alkalinity	7.7	28.0			Yes
10/21/2021	1st User for PH and EP-A for Alkalinity	7.8	27.6			Yes
10/22/2021	1st User for PH and EP-A for Alkalinity	8.0	28.5			Yes
10/23/2021	1st User for PH and EP-A for Alkalinity	7.8				Yes
10/24/2021	1st User for PH and EP-A for Alkalinity	7.8				Yes
10/25/2021	1st User for PH and EP-A for Alkalinity	7.8	28.4			Yes
10/26/2021	1st User for PH and EP-A for Alkalinity	7.2	25.3			Yes
10/27/2021	1st User for PH and EP-A for Alkalinity	7.2	26.5			Yes
10/28/2021	1st User for PH and EP-A for Alkalinity	7.3	26.1			Yes
10/29/2021	1st User for PH and EP-A for Alkalinity	7.6	25.8			Yes
10/30/2021	1st User for PH and EP-A for Alkalinity	7.2				Yes
10/31/2021	1st User for PH and EP-A for Alkalinity	7.5				Yes

Total number of excursions for PH during this monitoring period = 0
 Total number of excursions for Alkalinity during this monitoring period = 0

Send to dwp.dmce@state.or.us within 10 days after end of sampling period

For OHA use only:	
Minimum Water Quality	
Parameters as set by: DHS	
pH	7.2
Alk	23

Signature: 
 Print Name: Troy N. Trute
 Date: 11/1/2021