

Lead & Copper Rule Corrosion Control


PWS Name/ID: Neskowin Reg Water Dist - 4100970
Sample Period (Month/Year): January-22
Required Sample Frequency: Ph Every Day
Required Sample Frequency: Alaklinity 2 Samples Per Month

Day	Sample Location	pH	Alk	PO4	Other	yes/no
1/1/2022	1st User for PH and EP-A for Alkalinity	7.5				Yes
1/2/2022	1st User for PH and EP-A for Alkalinity	7.5				Yes
1/3/2022	1st User for PH and EP-A for Alkalinity	7.4	29.8			Yes
1/4/2022	1st User for PH and EP-A for Alkalinity	7.4	30.2			Yes
1/5/2022	1st User for PH and EP-A for Alkalinity	7.3	33.0			Yes
1/6/2022	1st User for PH and EP-A for Alkalinity	7.4	35.0			Yes
1/7/2022	1st User for PH and EP-A for Alkalinity	8.0	32.5			Yes
1/8/2022	1st User for PH and EP-A for Alkalinity	8.2				Yes
1/9/2022	1st User for PH and EP-A for Alkalinity	8.0				Yes
1/10/2022	1st User for PH and EP-A for Alkalinity	8.0	32.5			Yes
1/11/2022	1st User for PH and EP-A for Alkalinity	7.2	32.0			Yes
1/12/2022	1st User for PH and EP-A for Alkalinity	8.4	33.1			Yes
1/13/2022	1st User for PH and EP-A for Alkalinity	7.5	30.0			Yes
1/14/2022	1st User for PH and EP-A for Alkalinity	7.4	30.1			Yes
1/15/2022	1st User for PH and EP-A for Alkalinity	7.7				Yes
1/16/2022	1st User for PH and EP-A for Alkalinity	7.8				Yes
1/17/2022	1st User for PH and EP-A for Alkalinity	7.7	29.8			Yes
1/18/2022	1st User for PH and EP-A for Alkalinity	7.5	29.0			Yes
1/19/2022	1st User for PH and EP-A for Alkalinity	7.3	31.5			Yes
1/20/2022	1st User for PH and EP-A for Alkalinity	7.6	31.2			Yes
1/21/2022	1st User for PH and EP-A for Alkalinity	7.6	30.0			Yes
1/22/2022	1st User for PH and EP-A for Alkalinity	7.7				Yes
1/23/2022	1st User for PH and EP-A for Alkalinity	8.2				Yes
1/24/2022	1st User for PH and EP-A for Alkalinity	7.8	28.7			Yes
1/25/2022	1st User for PH and EP-A for Alkalinity	7.4	32.4			Yes
1/26/2022	1st User for PH and EP-A for Alkalinity	7.5	32.0			Yes
1/27/2022	1st User for PH and EP-A for Alkalinity	7.9	31.2			Yes
1/28/2022	1st User for PH and EP-A for Alkalinity	7.4	32.0			Yes
1/29/2022	1st User for PH and EP-A for Alkalinity	7.6				Yes
1/30/2022	1st User for PH and EP-A for Alkalinity	7.5				Yes
1/31/2022	1st User for PH and EP-A for Alkalinity	7.7	33.1			Yes

Total number of excursions for PH during this monitoring period = 0
 Total number of excursions for Alkalinity during this monitoring period = 0

Send to dwp.dmce@state.or.us within 10 days after end of sampling period

For OHA use only:	
Minimum Water Quality Parameters as set by: DHS	
pH	7.2
Alk	23

Signature: 
 Print Name: Troy N. Trute
 Date: 2/3/2022