

Water Quality Parameter Monitoring Form - EP-A and Distribution

**Lead & Copper Rule Corrosion Control**

PWS Name/ID: Neskowin Reg Water Dist - 4100970  
 Sample Period (Month/Year): July-22  
 Required Sample Frequency: Ph Every Day  
 Required Sample Frequency: Alaklinity 2 Samples Per Month

Day	Sample Location	pH	Alk	PO4	Other	yes/no
7/1/2022	1st User for PH and EP-A for Alkalinity	7.8	25.0			Yes
7/2/2022	1st User for PH and EP-A for Alkalinity	7.8				Yes
7/3/2022	1st User for PH and EP-A for Alkalinity	7.8				Yes
7/4/2022	1st User for PH and EP-A for Alkalinity	7.8	26.3			Yes
7/5/2022	1st User for PH and EP-A for Alkalinity	7.8	25.0			Yes
7/6/2022	1st User for PH and EP-A for Alkalinity	7.8	25.5			Yes
7/7/2022	1st User for PH and EP-A for Alkalinity	7.9	25.5			Yes
7/8/2022	1st User for PH and EP-A for Alkalinity	7.9	26.0			Yes
7/9/2022	1st User for PH and EP-A for Alkalinity	8.0				Yes
7/10/2022	1st User for PH and EP-A for Alkalinity	7.8				Yes
7/11/2022	1st User for PH and EP-A for Alkalinity	8.0	25.0			Yes
7/12/2022	1st User for PH and EP-A for Alkalinity	7.9	24.5			Yes
7/13/2022	1st User for PH and EP-A for Alkalinity	7.9	25.8			Yes
7/14/2022	1st User for PH and EP-A for Alkalinity	7.9	26.0			Yes
7/15/2022	1st User for PH and EP-A for Alkalinity	7.8	26.0			Yes
7/16/2022	1st User for PH and EP-A for Alkalinity	7.8	25.8			Yes
7/17/2022	1st User for PH and EP-A for Alkalinity	7.8				Yes
7/18/2022	1st User for PH and EP-A for Alkalinity	7.7				Yes
7/19/2022	1st User for PH and EP-A for Alkalinity	7.8	25.5			Yes
7/20/2022	1st User for PH and EP-A for Alkalinity	7.8	25.9			Yes
7/21/2022	1st User for PH and EP-A for Alkalinity	7.8	26.0			Yes
7/22/2022	1st User for PH and EP-A for Alkalinity	7.6	26.5			Yes
7/23/2022	1st User for PH and EP-A for Alkalinity	7.8	26.6			Yes
7/24/2022	1st User for PH and EP-A for Alkalinity	7.8				Yes
7/25/2022	1st User for PH and EP-A for Alkalinity	7.7				Yes
7/26/2022	1st User for PH and EP-A for Alkalinity	7.7	26.0			Yes
7/27/2022	1st User for PH and EP-A for Alkalinity	7.7	25.0			Yes
7/28/2022	1st User for PH and EP-A for Alkalinity	7.7	25.5			Yes
7/29/2022	1st User for PH and EP-A for Alkalinity	7.7	25.4			Yes
7/30/2022	1st User for PH and EP-A for Alkalinity	7.7	25.0			Yes
7/31/2022	1st User for PH and EP-A for Alkalinity	7.8				Yes

Total number of excursions for PH during this monitoring period = 0  
 Total number of excursions for Alkalinity during this monitoring period = 0

Send to [dwp.dmce@state.or.us](mailto:dwp.dmce@state.or.us) within 10 days after end of sampling period

For OHA use only:	
Minimum Water Quality Parameters as set by: DHS	
pH	7.2
Alk	23

Signature:   
 Print Name: Troy N. Trute  
 Date: 8/2/2022