

Water Quality Parameter Monitoring Form - EP-A and Distribution

Lead & Copper Rule Corrosion Control

PWS Name/ID: Neskowin Reg Water Dist - 4100970

Sample Period (Month/Year): May-23

Required Sample Frequency: Ph Every Day

Required Sample Frequency: Alaklinity 2 Samples Per Month


Day	Sample Location	pH	Alk	PO4	Other	yes/no
5/1/2023	1st User for PH and EP-A for Alkalinity	8.0	26.6			Yes
5/2/2023	1st User for PH and EP-A for Alkalinity	8.0	25.8			Yes
5/3/2023	1st User for PH and EP-A for Alkalinity	8.0	26.0			Yes
5/4/2023	1st User for PH and EP-A for Alkalinity	8.0	26.2			Yes
5/5/2023	1st User for PH and EP-A for Alkalinity	8.0	25.5			Yes
5/6/2023	1st User for PH and EP-A for Alkalinity	8.0				Yes
5/7/2023	1st User for PH and EP-A for Alkalinity	8.0				Yes
5/8/2023	1st User for PH and EP-A for Alkalinity	8.0	26.3			Yes
5/9/2023	1st User for PH and EP-A for Alkalinity	8.0	25.4			Yes
5/10/2023	1st User for PH and EP-A for Alkalinity	8.0	25.0			Yes
5/11/2023	1st User for PH and EP-A for Alkalinity	8.0	25.7			Yes
5/12/2023	1st User for PH and EP-A for Alkalinity	8.0	26.0			Yes
5/13/2023	1st User for PH and EP-A for Alkalinity	7.9				Yes
5/14/2023	1st User for PH and EP-A for Alkalinity	7.9				Yes
5/15/2023	1st User for PH and EP-A for Alkalinity	8.0	25.3			Yes
5/16/2023	1st User for PH and EP-A for Alkalinity	8.0	26.0			Yes
5/17/2023	1st User for PH and EP-A for Alkalinity	8.0	26.2			Yes
5/18/2023	1st User for PH and EP-A for Alkalinity	8.0	26.1			Yes
5/19/2023	1st User for PH and EP-A for Alkalinity	8.0	25.4			Yes
5/20/2023	1st User for PH and EP-A for Alkalinity	8.0				Yes
5/21/2023	1st User for PH and EP-A for Alkalinity	8.0				Yes
5/22/2023	1st User for PH and EP-A for Alkalinity	8.0	25.8			Yes
5/23/2023	1st User for PH and EP-A for Alkalinity	8.0	25.0			Yes
5/24/2023	1st User for PH and EP-A for Alkalinity	8.0	25.4			Yes
5/25/2023	1st User for PH and EP-A for Alkalinity	8.0	24.8			Yes
5/26/2023	1st User for PH and EP-A for Alkalinity	8.0	25.2			Yes
5/27/2023	1st User for PH and EP-A for Alkalinity	8.0				Yes
5/28/2023	1st User for PH and EP-A for Alkalinity	8.0				Yes
5/29/2023	1st User for PH and EP-A for Alkalinity	8.0	26.8			Yes
5/30/2023	1st User for PH and EP-A for Alkalinity	8.0	27.0			Yes
5/31/2023	1st User for PH and EP-A for Alkalinity	8.0	25.8			Yes

Total number of excursions for PH during this monitoring period = 0

Total number of excursions for Alkalinity during this monitoring period = 0

Send to dwp.dmce@state.or.us within 10 days after end of sampling period

For OHA use only:	
Minimum Water Quality Parameters as set by: DHS	
pH	7.2
Alk	23

Signature: 

Print Name: Troy N. Trute

Date: 6/6/2023