

Water Quality Parameter Monitoring Form - EP-A and Distribution

Lead & Copper Rule Corrosion Control


PWS Name/ID: Neskowin Reg Water Dist - 4100970
Sample Period (Month/Year): June-23
Required Sample Frequency: Ph Every Day
Required Sample Frequency: Alaklinity 2 Samples Per Month

Day	Sample Location	pH	Alk	PO4	Other	yes/no
6/1/2023	1st User for PH and EP-A for Alkalinity	8.0	26.0			Yes
6/2/2023	1st User for PH and EP-A for Alkalinity	8.0	26.4			Yes
6/3/2023	1st User for PH and EP-A for Alkalinity	8.0				Yes
6/4/2023	1st User for PH and EP-A for Alkalinity	8.0				Yes
6/5/2023	1st User for PH and EP-A for Alkalinity	8.0	25.8			Yes
6/6/2023	1st User for PH and EP-A for Alkalinity	8.0	26.0			Yes
6/7/2023	1st User for PH and EP-A for Alkalinity	8.0	26.4			Yes
6/8/2023	1st User for PH and EP-A for Alkalinity	7.4	26.0			Yes
6/9/2023	1st User for PH and EP-A for Alkalinity	7.5	26.4			Yes
6/10/2023	1st User for PH and EP-A for Alkalinity	7.5				Yes
6/11/2023	1st User for PH and EP-A for Alkalinity	7.6				Yes
6/12/2023	1st User for PH and EP-A for Alkalinity	8.0	25.4			Yes
6/13/2023	1st User for PH and EP-A for Alkalinity	8.0	25.5			Yes
6/14/2023	1st User for PH and EP-A for Alkalinity	8.0	25.8			Yes
6/15/2023	1st User for PH and EP-A for Alkalinity	8.0	26.0			Yes
6/16/2023	1st User for PH and EP-A for Alkalinity	8.0	26.0			Yes
6/17/2023	1st User for PH and EP-A for Alkalinity	8.0				Yes
6/18/2023	1st User for PH and EP-A for Alkalinity	8.0				Yes
6/19/2023	1st User for PH and EP-A for Alkalinity	8.0	26.8			Yes
6/20/2023	1st User for PH and EP-A for Alkalinity	8.0	26.4			Yes
6/21/2023	1st User for PH and EP-A for Alkalinity	8.0	26.0			Yes
6/22/2023	1st User for PH and EP-A for Alkalinity	8.0	24.8			Yes
6/23/2023	1st User for PH and EP-A for Alkalinity	8.0	25.8			Yes
6/24/2023	1st User for PH and EP-A for Alkalinity	7.6				Yes
6/25/2023	1st User for PH and EP-A for Alkalinity	7.6				Yes
6/26/2023	1st User for PH and EP-A for Alkalinity	8.0	25.6			Yes
6/27/2023	1st User for PH and EP-A for Alkalinity	8.0	26.0			Yes
6/28/2023	1st User for PH and EP-A for Alkalinity	8.0	26.1			Yes
6/29/2023	1st User for PH and EP-A for Alkalinity	8.0	26.0			Yes
6/30/2023	1st User for PH and EP-A for Alkalinity	8.0	25.8			Yes

Total number of excursions for PH during this monitoring period = 0
 Total number of excursions for Alkalinity during this monitoring period = 0

Send to dwp.dmce@state.or.us within 10 days after end of sampling period

For OHA use only:	
Minimum Water Quality Parameters as set by: DHS	
pH	7.2
Alk	23

Signature: 
 Print Name: Troy N. Trute
 Date: 7/3/2023