

Water Quality Parameter Monitoring Form - EP-A and Distribution

**Lead & Copper Rule Corrosion Control**


**PWS Name/ID:** Neskowin Reg Water Dist - 4100970  
**Sample Period (Month/Year):** October-23  
**Required Sample Frequency:** Ph Every Day  
**Required Sample Frequency:** Alaklinity 2 Samples Per Month

Day	Sample Location	pH	Alk	PO4	Other	yes/no
10/1/2023	1st User for PH and EP-A for Alkalinity	7.8				Yes
10/2/2023	1st User for PH and EP-A for Alkalinity	8.0	26.2			Yes
10/3/2023	1st User for PH and EP-A for Alkalinity	7.9	25.0			Yes
10/4/2023	1st User for PH and EP-A for Alkalinity	7.9	25.3			Yes
10/5/2023	1st User for PH and EP-A for Alkalinity	7.9	25.6			Yes
10/6/2023	1st User for PH and EP-A for Alkalinity	7.9	25.0			Yes
10/7/2023	1st User for PH and EP-A for Alkalinity	7.9				Yes
10/8/2023	1st User for PH and EP-A for Alkalinity	7.9				Yes
10/9/2023	1st User for PH and EP-A for Alkalinity	7.8	26.0			Yes
10/10/2023	1st User for PH and EP-A for Alkalinity	7.9	26.0			Yes
10/11/2023	1st User for PH and EP-A for Alkalinity	7.9	25.2			Yes
10/12/2023	1st User for PH and EP-A for Alkalinity	7.8	25.5			Yes
10/13/2023	1st User for PH and EP-A for Alkalinity	7.8	25.4			Yes
10/14/2023	1st User for PH and EP-A for Alkalinity	7.8				Yes
10/15/2023	1st User for PH and EP-A for Alkalinity	7.8				Yes
10/16/2023	1st User for PH and EP-A for Alkalinity	7.8	25.0			Yes
10/17/2023	1st User for PH and EP-A for Alkalinity	7.8	24.8			Yes
10/18/2023	1st User for PH and EP-A for Alkalinity	7.8	24.9			Yes
10/19/2023	1st User for PH and EP-A for Alkalinity	7.8	25.3			Yes
10/20/2023	1st User for PH and EP-A for Alkalinity	7.8	25.0			Yes
10/21/2023	1st User for PH and EP-A for Alkalinity	7.8				Yes
10/22/2023	1st User for PH and EP-A for Alkalinity	7.9				Yes
10/23/2023	1st User for PH and EP-A for Alkalinity	7.8	25.2			Yes
10/24/2023	1st User for PH and EP-A for Alkalinity	7.9	24.6			Yes
10/25/2023	1st User for PH and EP-A for Alkalinity	7.8	24.6			Yes
10/26/2023	1st User for PH and EP-A for Alkalinity	7.8	25.0			Yes
10/27/2023	1st User for PH and EP-A for Alkalinity	7.8	25.5			Yes
10/28/2023	1st User for PH and EP-A for Alkalinity	7.8				Yes
10/29/2023	1st User for PH and EP-A for Alkalinity	7.8				Yes
10/30/2023	1st User for PH and EP-A for Alkalinity	7.8	26.2			Yes
10/31/2023	1st User for PH and EP-A for Alkalinity	7.8	25.5			Yes

Total number of excursions for PH during this monitoring period = 0  
 Total number of excursions for Alkalinity during this monitoring period = 0

Send to [dvp.dmce@state.or.us](mailto:dvp.dmce@state.or.us) within 10 days after end of sampling period

For OHA use only:	
Minimum Water Quality	
Parameters as set by: DHS	
pH	7.2
Alk	23

Signature:   
 Print Name: Troy N. Trute  
 Date: 11/8/2023