

Water Quality Parameter Monitoring Form - EP-A and Distribution

**Lead & Copper Rule Corrosion Control**

**PWS Name/ID:** Neskowin Reg Water Dist - 4100970

**Sample Period (Month/Year):** November-23

**Required Sample Frequency:** Ph Every Day

**Required Sample Frequency:** Alaklinity 2 Samples Per Month


Day	Sample Location	pH	Alk	PO4	Other	yes/no
11/1/2023	1st User for PH and EP-A for Alkalinity	7.8	26.8			Yes
11/2/2023	1st User for PH and EP-A for Alkalinity	7.8	27.0			Yes
11/3/2023	1st User for PH and EP-A for Alkalinity	7.8	26.5			Yes
11/4/2023	1st User for PH and EP-A for Alkalinity	7.8				Yes
11/5/2023	1st User for PH and EP-A for Alkalinity	7.8				Yes
11/6/2023	1st User for PH and EP-A for Alkalinity	7.8	25.4			Yes
11/7/2023	1st User for PH and EP-A for Alkalinity	8.0	25.0			Yes
11/8/2023	1st User for PH and EP-A for Alkalinity	8.0	25.4			Yes
11/9/2023	1st User for PH and EP-A for Alkalinity	8.0	25.9			Yes
11/10/2023	1st User for PH and EP-A for Alkalinity	7.8	26.0			Yes
11/11/2023	1st User for PH and EP-A for Alkalinity	7.8				Yes
11/12/2023	1st User for PH and EP-A for Alkalinity	7.8				Yes
11/13/2023	1st User for PH and EP-A for Alkalinity	8.0	26.4			Yes
11/14/2023	1st User for PH and EP-A for Alkalinity	7.8	26.5			Yes
11/15/2023	1st User for PH and EP-A for Alkalinity	7.8	26.0			Yes
11/16/2023	1st User for PH and EP-A for Alkalinity	8.0	25.9			Yes
11/17/2023	1st User for PH and EP-A for Alkalinity	8.0	26.4			Yes
11/18/2023	1st User for PH and EP-A for Alkalinity	8.0				Yes
11/19/2023	1st User for PH and EP-A for Alkalinity	8.0				Yes
11/20/2023	1st User for PH and EP-A for Alkalinity	8.0	26.7			Yes
11/21/2023	1st User for PH and EP-A for Alkalinity	8.0	24.8			Yes
11/22/2023	1st User for PH and EP-A for Alkalinity	8.0	25.0			Yes
11/23/2023	1st User for PH and EP-A for Alkalinity	8.0	25.8			Yes
11/24/2023	1st User for PH and EP-A for Alkalinity	8.0	26.0			Yes
11/25/2023	1st User for PH and EP-A for Alkalinity	8.0				Yes
11/26/2023	1st User for PH and EP-A for Alkalinity	8.0	26.4			Yes
11/27/2023	1st User for PH and EP-A for Alkalinity	8.0	26.5			Yes
11/28/2023	1st User for PH and EP-A for Alkalinity	8.0	24.7			Yes
11/29/2023	1st User for PH and EP-A for Alkalinity	8.0	24.9			Yes
11/30/2023	1st User for PH and EP-A for Alkalinity	8.0	26.0			Yes

Total number of excursions for PH during this monitoring period = 0

Total number of excursions for Alkalinity during this monitoring period = 0

Send to [dwp.dmce@state.or.us](mailto:dwp.dmce@state.or.us) within 10 days after end of sampling period

For OHA use only:	
Minimum Water Quality Parameters as set by: DHS	
pH	7.2
Alk	23

Signature: 

Print Name: Troy N. Trute

Date: 12/6/2023