

Water Quality Parameter Monitoring Form - EP-A and Distribution

Lead & Copper Rule Corrosion Control


PWS Name/ID: Neskowin Reg Water Dist - 4100970
Sample Period (Month/Year): December-23
Required Sample Frequency: Ph Every Day
Required Sample Frequency: Alaklinity 2 Samples Per Month

Day	Sample Location	pH	Alk	PO4	Other	yes/no
12/1/2023	1st User for PH and EP-A for Alkalinity	8.1	26.0			Yes
12/2/2023	1st User for PH and EP-A for Alkalinity	8.0				Yes
12/3/2023	1st User for PH and EP-A for Alkalinity	8.0				Yes
12/4/2023	1st User for PH and EP-A for Alkalinity	8.0	25.6			Yes
12/5/2023	1st User for PH and EP-A for Alkalinity	8.0	25.0			Yes
12/6/2023	1st User for PH and EP-A for Alkalinity	8.0	25.8			Yes
12/7/2023	1st User for PH and EP-A for Alkalinity	8.0	25.9			Yes
12/8/2023	1st User for PH and EP-A for Alkalinity	8.0	26.2			Yes
12/9/2023	1st User for PH and EP-A for Alkalinity	8.0				Yes
12/10/2023	1st User for PH and EP-A for Alkalinity	8.0				Yes
12/11/2023	1st User for PH and EP-A for Alkalinity	8.0	26.4			Yes
12/12/2023	1st User for PH and EP-A for Alkalinity	8.0	26.0			Yes
12/13/2023	1st User for PH and EP-A for Alkalinity	8.0	26.0			Yes
12/14/2023	1st User for PH and EP-A for Alkalinity	8.0	26.4			Yes
12/15/2023	1st User for PH and EP-A for Alkalinity	8.0	25.8			Yes
12/16/2023	1st User for PH and EP-A for Alkalinity	8.0				Yes
12/17/2023	1st User for PH and EP-A for Alkalinity	8.0				Yes
12/18/2023	1st User for PH and EP-A for Alkalinity	8.0	25.7			Yes
12/19/2023	1st User for PH and EP-A for Alkalinity	8.0	25.4			Yes
12/20/2023	1st User for PH and EP-A for Alkalinity	8.0	25.9			Yes
12/21/2023	1st User for PH and EP-A for Alkalinity	8.0	26.0			Yes
12/22/2023	1st User for PH and EP-A for Alkalinity	8.0	26.6			Yes
12/23/2023	1st User for PH and EP-A for Alkalinity	8.0				Yes
12/24/2023	1st User for PH and EP-A for Alkalinity	8.0				Yes
12/25/2023	1st User for PH and EP-A for Alkalinity	8.0	26.6			Yes
12/26/2023	1st User for PH and EP-A for Alkalinity	8.0	26.0			Yes
12/27/2023	1st User for PH and EP-A for Alkalinity	8.0	26.4			Yes
12/28/2023	1st User for PH and EP-A for Alkalinity	8.0	26.1			Yes
12/29/2023	1st User for PH and EP-A for Alkalinity	8.0	26.8			Yes
12/30/2023	1st User for PH and EP-A for Alkalinity	8.0				Yes
12/31/2023	1st User for PH and EP-A for Alkalinity	8.0				Yes

Total number of excursions for PH during this monitoring period = 0
 Total number of excursions for Alkalinity during this monitoring period = 0

Send to dwp.dmce@state.or.us within 10 days after end of sampling period

For OHA use only:	
Minimum Water Quality Parameters as set by: DHS	
pH	7.2
Alk	23

Signature: 
 Print Name: Troy N. Trute
 Date: 1/3/2024