

Water Quality Parameter Monitoring Form - EP-A and Distribution

Lead & Copper Rule Corrosion Control


PWS Name/ID: Neskowin Reg Water Dist - 4100970
Sample Period (Month/Year): February-24
Required Sample Frequency: Ph Every Day
Required Sample Frequency: Alaklinity 2 Samples Per Month

Day	Sample Location	pH	Alk	PO4	Other	yes/no
2/1/2024	1st User for PH and EP-A for Alkalinity	8.0	26.5			Yes
2/2/2024	1st User for PH and EP-A for Alkalinity	8.0	26.4			Yes
2/3/2024	1st User for PH and EP-A for Alkalinity	8.0				Yes
2/4/2024	1st User for PH and EP-A for Alkalinity	8.0				Yes
2/5/2024	1st User for PH and EP-A for Alkalinity	8.0	25.8			Yes
2/6/2024	1st User for PH and EP-A for Alkalinity	8.0	25.4			Yes
2/7/2024	1st User for PH and EP-A for Alkalinity	8.0	25.0			Yes
2/8/2024	1st User for PH and EP-A for Alkalinity	8.0	25.8			Yes
2/9/2024	1st User for PH and EP-A for Alkalinity	8.0	26.3			Yes
2/10/2024	1st User for PH and EP-A for Alkalinity	8.0				Yes
2/11/2024	1st User for PH and EP-A for Alkalinity	8.0				Yes
2/12/2024	1st User for PH and EP-A for Alkalinity	8.0	26.2			Yes
2/13/2024	1st User for PH and EP-A for Alkalinity	8.0	26.0			Yes
2/14/2024	1st User for PH and EP-A for Alkalinity	8.0	25.4			Yes
2/15/2024	1st User for PH and EP-A for Alkalinity	8.0	25.5			Yes
2/16/2024	1st User for PH and EP-A for Alkalinity	8.0	25.5			Yes
2/17/2024	1st User for PH and EP-A for Alkalinity	8.0				Yes
2/18/2024	1st User for PH and EP-A for Alkalinity	8.0				Yes
2/19/2024	1st User for PH and EP-A for Alkalinity	8.0	26.7			Yes
2/20/2024	1st User for PH and EP-A for Alkalinity	8.0	26.1			Yes
2/21/2024	1st User for PH and EP-A for Alkalinity	8.0	26.0			Yes
2/22/2024	1st User for PH and EP-A for Alkalinity	8.0	25.7			Yes
2/23/2024	1st User for PH and EP-A for Alkalinity	8.0	25.9			Yes
2/24/2024	1st User for PH and EP-A for Alkalinity	8.0				Yes
2/25/2024	1st User for PH and EP-A for Alkalinity	8.0				Yes
2/26/2024	1st User for PH and EP-A for Alkalinity	8.0	27.0			Yes
2/27/2024	1st User for PH and EP-A for Alkalinity	8.0	26.5			Yes
2/28/2024	1st User for PH and EP-A for Alkalinity	8.0	26.4			Yes
2/29/2024	1st User for PH and EP-A for Alkalinity	8.0	26.7			Yes

Total number of excursions for PH during this monitoring period = 0
 Total number of excursions for Alkalinity during this monitoring period = 0

Send to dvp.dmce@state.or.us within 10 days after end of sampling period

For OHA use only:	
Minimum Water Quality Parameters as set by: DHS	
pH	7.2
Alk	23

Signature: 
 Print Name: Troy N. Trute
 Date: 3/5/2024