

Water Quality Parameter Monitoring Form - EP-A and Distribution

Lead & Copper Rule Corrosion Control

PWS Name/ID: Neskowin Reg Water Dist - 4100970

Sample Period (Month/Year): March-24

Required Sample Frequency: Ph Every Day

Required Sample Frequency: Alaklinity 2 Samples Per Month


Day	Sample Location	pH	Alk	PO4	Other	yes/no
3/1/2024	1st User for PH and EP-A for Alkalinity	8.0	25.9			Yes
3/2/2024	1st User for PH and EP-A for Alkalinity	8.0				Yes
3/3/2024	1st User for PH and EP-A for Alkalinity	8.0				Yes
3/4/2024	1st User for PH and EP-A for Alkalinity	8.0	26.2			Yes
3/5/2024	1st User for PH and EP-A for Alkalinity	8.0	26.0			Yes
3/6/2024	1st User for PH and EP-A for Alkalinity	8.0	25.4			Yes
3/7/2024	1st User for PH and EP-A for Alkalinity	8.0	25.7			Yes
3/8/2024	1st User for PH and EP-A for Alkalinity	8.0	25.9			Yes
3/9/2024	1st User for PH and EP-A for Alkalinity	8.0				Yes
3/10/2024	1st User for PH and EP-A for Alkalinity	8.0				Yes
3/11/2024	1st User for PH and EP-A for Alkalinity	8.0	26.6			Yes
3/12/2024	1st User for PH and EP-A for Alkalinity	8.0	26.8			Yes
3/13/2024	1st User for PH and EP-A for Alkalinity	8.0	25.6			Yes
3/14/2024	1st User for PH and EP-A for Alkalinity	8.0	25.9			Yes
3/15/2024	1st User for PH and EP-A for Alkalinity	8.0	25.0			Yes
3/16/2024	1st User for PH and EP-A for Alkalinity	8.0				Yes
3/17/2024	1st User for PH and EP-A for Alkalinity	8.0				Yes
3/18/2024	1st User for PH and EP-A for Alkalinity	8.0	26.2			Yes
3/19/2024	1st User for PH and EP-A for Alkalinity	8.0	26.2			Yes
3/20/2024	1st User for PH and EP-A for Alkalinity	8.0	26.0			Yes
3/21/2024	1st User for PH and EP-A for Alkalinity	8.0	25.4			Yes
3/22/2024	1st User for PH and EP-A for Alkalinity	8.0	25.5			Yes
3/23/2024	1st User for PH and EP-A for Alkalinity	8.0				Yes
3/24/2024	1st User for PH and EP-A for Alkalinity	8.0				Yes
3/25/2024	1st User for PH and EP-A for Alkalinity	8.0	26.7			Yes
3/26/2024	1st User for PH and EP-A for Alkalinity	8.0	26.0			Yes
3/27/2024	1st User for PH and EP-A for Alkalinity	8.0	26.2			Yes
3/28/2024	1st User for PH and EP-A for Alkalinity	8.0	26.1			Yes
3/29/2024	1st User for PH and EP-A for Alkalinity	8.0	25.7			Yes
3/30/2024	1st User for PH and EP-A for Alkalinity	8.0				Yes
3/31/2024	1st User for PH and EP-A for Alkalinity	8.0				Yes

Total number of excursions for PH during this monitoring period = 0

Total number of excursions for Alkalinity during this monitoring period = 0

Send to dwp.dmce@state.or.us within 10 days after end of sampling period

For OHA use only:	
Minimum Water Quality	
Parameters as set by: DHS	
pH	7.2
Alk	23

Signature: 

Print Name: Troy N. Trute

Date: 4/9/2024