

Water Quality Parameter Monitoring Form - EP-A and Distribution

Lead & Copper Rule Corrosion Control


PWS Name/ID: Neskowin Reg Water Dist - 4100970
Sample Period (Month/Year): August-24
Required Sample Frequency: Ph Every Day
Required Sample Frequency: Alaklinity 2 Samples Per Month

Day	Sample Location	pH	Alk	PO4	Other	yes/no
8/1/2024	1st User for PH and EP-A for Alkalinity	8.2	26.1			Yes
8/2/2024	1st User for PH and EP-A for Alkalinity	8.0	26.2			Yes
8/3/2024	1st User for PH and EP-A for Alkalinity	8.0				Yes
8/4/2024	1st User for PH and EP-A for Alkalinity	8.0				Yes
8/5/2024	1st User for PH and EP-A for Alkalinity	8.0	25.4			Yes
8/6/2024	1st User for PH and EP-A for Alkalinity	8.0	25.5			Yes
8/7/2024	1st User for PH and EP-A for Alkalinity	8.2	25.7			Yes
8/8/2024	1st User for PH and EP-A for Alkalinity	8.2	26.0			Yes
8/9/2024	1st User for PH and EP-A for Alkalinity	8.2	25.7			Yes
8/10/2024	1st User for PH and EP-A for Alkalinity	8.0				Yes
8/11/2024	1st User for PH and EP-A for Alkalinity	8.0				Yes
8/12/2024	1st User for PH and EP-A for Alkalinity	8.0	26.2			Yes
8/13/2024	1st User for PH and EP-A for Alkalinity	8.2	26.2			Yes
8/14/2024	1st User for PH and EP-A for Alkalinity	8.2	26.4			Yes
8/15/2024	1st User for PH and EP-A for Alkalinity	8.2	26.0			Yes
8/16/2024	1st User for PH and EP-A for Alkalinity	8.0	25.9			Yes
8/17/2024	1st User for PH and EP-A for Alkalinity	8.0				Yes
8/18/2024	1st User for PH and EP-A for Alkalinity	8.0				Yes
8/19/2024	1st User for PH and EP-A for Alkalinity	8.0	25.7			Yes
8/20/2024	1st User for PH and EP-A for Alkalinity	8.0	25.6			Yes
8/21/2024	1st User for PH and EP-A for Alkalinity	7.8	25.7			Yes
8/22/2024	1st User for PH and EP-A for Alkalinity	7.8	26.0			Yes
8/23/2024	1st User for PH and EP-A for Alkalinity	7.8	26.3			Yes
8/24/2024	1st User for PH and EP-A for Alkalinity	7.8				Yes
8/25/2024	1st User for PH and EP-A for Alkalinity	7.8				Yes
8/26/2024	1st User for PH and EP-A for Alkalinity	7.8	26.0			Yes
8/27/2024	1st User for PH and EP-A for Alkalinity	7.8	26.0			Yes
8/28/2024	1st User for PH and EP-A for Alkalinity	7.8	26.3			Yes
8/29/2024	1st User for PH and EP-A for Alkalinity	7.8	26.1			Yes
8/30/2024	1st User for PH and EP-A for Alkalinity	7.8	25.9			Yes
8/31/2024	1st User for PH and EP-A for Alkalinity	7.8				Yes

Total number of excursions for PH during this monitoring period = 0
 Total number of excursions for Alkalinity during this monitoring period = 0

Send to dwp.dmce@state.or.us within 10 days after end of sampling period

For OHA use only:	
Minimum Water Quality Parameters as set by: DHS	
pH	7.2
Alk	23

Signature: 
 Print Name: Troy N. Trute
 Date: 9/5/2024