

Water Quality Parameter Monitoring Form - EP-A and Distribution

**Lead & Copper Rule Corrosion Control**


**PWS Name/ID:** Neskowin Reg Water Dist - 4100970  
**Sample Period (Month/Year):** October-24  
**Required Sample Frequency:** Ph Every Day  
**Required Sample Frequency:** Alaklinity 2 Samples Per Month

Day	Sample Location	pH	Alk	PO4	Other	yes/no
10/1/2024	1st User for PH and EP-A for Alkalinity	7.8	26.0			Yes
10/2/2024	1st User for PH and EP-A for Alkalinity	8.0	26.5			Yes
10/3/2024	1st User for PH and EP-A for Alkalinity	8.0	26.4			Yes
10/4/2024	1st User for PH and EP-A for Alkalinity	8.0	26.0			Yes
10/5/2024	1st User for PH and EP-A for Alkalinity	8.0				Yes
10/6/2024	1st User for PH and EP-A for Alkalinity	7.8				Yes
10/7/2024	1st User for PH and EP-A for Alkalinity	8.0	25.8			Yes
10/8/2024	1st User for PH and EP-A for Alkalinity	8.0	25.5			Yes
10/9/2024	1st User for PH and EP-A for Alkalinity	8.0	26.0			Yes
10/10/2024	1st User for PH and EP-A for Alkalinity	8.0	26.3			Yes
10/11/2024	1st User for PH and EP-A for Alkalinity	8.0	26.0			Yes
10/12/2024	1st User for PH and EP-A for Alkalinity	8.0				Yes
10/13/2024	1st User for PH and EP-A for Alkalinity	7.8				Yes
10/14/2024	1st User for PH and EP-A for Alkalinity	7.8	26.8			Yes
10/15/2024	1st User for PH and EP-A for Alkalinity	7.8	25.9			Yes
10/16/2024	1st User for PH and EP-A for Alkalinity	7.9	26.0			Yes
10/17/2024	1st User for PH and EP-A for Alkalinity	7.9	26.3			Yes
10/18/2024	1st User for PH and EP-A for Alkalinity	7.8	26.4			Yes
10/19/2024	1st User for PH and EP-A for Alkalinity	7.8				Yes
10/20/2024	1st User for PH and EP-A for Alkalinity	7.8				Yes
10/21/2024	1st User for PH and EP-A for Alkalinity	8.0	26.5			Yes
10/22/2024	1st User for PH and EP-A for Alkalinity	8.0	26.4			Yes
10/23/2024	1st User for PH and EP-A for Alkalinity	8.0	26.0			Yes
10/24/2024	1st User for PH and EP-A for Alkalinity	8.0	26.8			Yes
10/25/2024	1st User for PH and EP-A for Alkalinity	8.0	26.9			Yes
10/26/2024	1st User for PH and EP-A for Alkalinity	8.0				Yes
10/27/2024	1st User for PH and EP-A for Alkalinity	8.0				Yes
10/28/2024	1st User for PH and EP-A for Alkalinity	8.0	27.0			Yes
10/29/2024	1st User for PH and EP-A for Alkalinity	8.0	27.2			Yes
10/30/2024	1st User for PH and EP-A for Alkalinity	8.0	26.5			Yes
10/31/2024	1st User for PH and EP-A for Alkalinity	8.0	26.0			Yes

Total number of excursions for PH during this monitoring period = 0  
 Total number of excursions for Alkalinity during this monitoring period = 0

Send to [dwp.dmce@state.or.us](mailto:dwp.dmce@state.or.us) within 10 days after end of sampling period

For OHA use only:	
Minimum Water Quality Parameters as set by: DHS	
pH	7.2
Alk	23

Signature:   
 Print Name: Troy N. Trute  
 Date: 11/6/2024