

Water Quality Parameter Monitoring Form - EP-A and Distribution

Lead & Copper Rule Corrosion Control

PWS Name/ID: Neskowin Reg Water Dist - 4100970

Sample Period (Month/Year): December-24

Required Sample Frequency: Ph Every Day

Required Sample Frequency: Alaklinity 2 Samples Per Month


Day	Sample Location	pH	Alk	PO4	Other	yes/no
12/1/2024	1st User for PH and EP-A for Alkalinity	7.7				Yes
12/2/2024	1st User for PH and EP-A for Alkalinity	7.6	26.5			Yes
12/3/2024	1st User for PH and EP-A for Alkalinity	7.6	26.0			Yes
12/4/2024	1st User for PH and EP-A for Alkalinity	7.6	26.3			Yes
12/5/2024	1st User for PH and EP-A for Alkalinity	7.6	26.5			Yes
12/6/2024	1st User for PH and EP-A for Alkalinity	7.7	25.8			Yes
12/7/2024	1st User for PH and EP-A for Alkalinity	7.7				Yes
12/8/2024	1st User for PH and EP-A for Alkalinity	7.7				Yes
12/9/2024	1st User for PH and EP-A for Alkalinity	7.8	25.8			Yes
12/10/2024	1st User for PH and EP-A for Alkalinity	7.8	25.9			Yes
12/11/2024	1st User for PH and EP-A for Alkalinity	7.6	26.3			Yes
12/12/2024	1st User for PH and EP-A for Alkalinity	7.6	26.2			Yes
12/13/2024	1st User for PH and EP-A for Alkalinity	7.7	26.0			Yes
12/14/2024	1st User for PH and EP-A for Alkalinity	7.7				Yes
12/15/2024	1st User for PH and EP-A for Alkalinity	7.7				Yes
12/16/2024	1st User for PH and EP-A for Alkalinity	7.8	25.7			Yes
12/17/2024	1st User for PH and EP-A for Alkalinity	7.8	26.8			Yes
12/18/2024	1st User for PH and EP-A for Alkalinity	7.8	26.8			Yes
12/19/2024	1st User for PH and EP-A for Alkalinity	7.8	26.3			Yes
12/20/2024	1st User for PH and EP-A for Alkalinity	7.8	26.5			Yes
12/21/2024	1st User for PH and EP-A for Alkalinity	7.8				Yes
12/22/2024	1st User for PH and EP-A for Alkalinity	7.8				Yes
12/23/2024	1st User for PH and EP-A for Alkalinity	7.8	26.4			Yes
12/24/2024	1st User for PH and EP-A for Alkalinity	7.8	26.0			Yes
12/25/2024	1st User for PH and EP-A for Alkalinity	7.8	26.0			Yes
12/26/2024	1st User for PH and EP-A for Alkalinity	7.8	26.5			Yes
12/27/2024	1st User for PH and EP-A for Alkalinity	7.8	26.7			Yes
12/28/2024	1st User for PH and EP-A for Alkalinity	7.8				Yes
12/29/2024	1st User for PH and EP-A for Alkalinity	7.8				Yes
12/30/2024	1st User for PH and EP-A for Alkalinity	7.8	26.0			Yes
12/31/2024	1st User for PH and EP-A for Alkalinity	7.8	25.8			Yes

Total number of excursions for PH during this monitoring period = 0

Total number of excursions for Alkalinity during this monitoring period = 0

Send to dwp.dmce@state.or.us within 10 days after end of sampling period

For OHA use only:	
Minimum Water Quality	
Parameters as set by: DHS	
pH	7.2
Alk	23

Signature: 

Print Name: Troy N. Trute

Date: 1/8/2025