

**Lead & Copper Rule Corrosion Control**

PWS Name/ID:

Neskowin Reg Water Dist - 4100970

Sample Period (Month/Year):

April-25

Required Sample Frequency:

Ph Every Day

Required Sample Frequency:

Alaklinity 2 Samples Per Month

Day	Sample Location	pH	Alk	PO4	Other	yes/no
4/1/2025	1st User for PH and EP-A for Alkalinity	7.8	26.5			Yes
4/2/2025	1st User for PH and EP-A for Alkalinity	7.8	26.3			Yes
4/3/2025	1st User for PH and EP-A for Alkalinity	7.8	26.0			Yes
4/4/2025	1st User for PH and EP-A for Alkalinity	7.8	26.0			Yes
4/5/2025	1st User for PH and EP-A for Alkalinity	7.8				Yes
4/6/2025	1st User for PH and EP-A for Alkalinity	7.8				Yes
4/7/2025	1st User for PH and EP-A for Alkalinity	7.8	25.8			Yes
4/8/2025	1st User for PH and EP-A for Alkalinity	7.8	26.5			Yes
4/9/2025	1st User for PH and EP-A for Alkalinity	7.8	26.0			Yes
4/10/2025	1st User for PH and EP-A for Alkalinity	7.8	26.5			Yes
4/11/2025	1st User for PH and EP-A for Alkalinity	7.8	26.3			Yes
4/12/2025	1st User for PH and EP-A for Alkalinity	7.8				Yes
4/13/2025	1st User for PH and EP-A for Alkalinity	7.8				Yes
4/14/2025	1st User for PH and EP-A for Alkalinity	7.8	26.7			Yes
4/15/2025	1st User for PH and EP-A for Alkalinity	7.8	26.8			Yes
4/16/2025	1st User for PH and EP-A for Alkalinity	7.8	26.5			Yes
4/17/2025	1st User for PH and EP-A for Alkalinity	7.8	26.0			Yes
4/18/2025	1st User for PH and EP-A for Alkalinity	7.8	26.0			Yes
4/19/2025	1st User for PH and EP-A for Alkalinity	7.8				Yes
4/20/2025	1st User for PH and EP-A for Alkalinity	7.8				Yes
4/21/2025	1st User for PH and EP-A for Alkalinity	7.8	26.3			Yes
4/22/2025	1st User for PH and EP-A for Alkalinity	7.8	26.5			Yes
4/23/2025	1st User for PH and EP-A for Alkalinity	7.8	26.4			Yes
4/24/2025	1st User for PH and EP-A for Alkalinity	7.8	26.0			Yes
4/25/2025	1st User for PH and EP-A for Alkalinity	7.8	26.8			Yes
4/26/2025	1st User for PH and EP-A for Alkalinity	7.8				Yes
4/27/2025	1st User for PH and EP-A for Alkalinity	7.8				Yes
4/28/2025	1st User for PH and EP-A for Alkalinity	7.8	26.4			Yes
4/29/2025	1st User for PH and EP-A for Alkalinity	7.8	26.8			Yes
4/30/2025	1st User for PH and EP-A for Alkalinity	7.8	26.4			Yes

Total number of excursions for PH during this monitoring period =

0

Total number of excursions for Alkalinity during this monitoring period =

0

Send to [dwp.dmce@state.or.us](mailto:dwp.dmce@state.or.us) within 10 days after end of sampling period

For OHA use only:

Minimum Water Quality


Parameters as set by: DHS

pH	7.2
Alk	23

Signature:

Print Name:

Date:

  
 Troy N. Trute  
 5/2/2025