

Lead & Copper Rule Corrosion Control

PWS Name/ID:

Neskowin Reg Water Dist - 4100970

Sample Period (Month/Year):

May-25

Required Sample Frequency:

Ph Every Day

Required Sample Frequency:

Alaklinity 2 Samples Per Month

Day	Sample Location	pH	Alk	PO4	Other	yes/no
5/1/2025	1st User for PH and EP-A for Alkalinity	7.8	26.5			Yes
5/2/2025	1st User for PH and EP-A for Alkalinity	7.8	26.0			Yes
5/3/2025	1st User for PH and EP-A for Alkalinity	7.8				Yes
5/4/2025	1st User for PH and EP-A for Alkalinity	7.8				Yes
5/5/2025	1st User for PH and EP-A for Alkalinity	7.8	25.9			Yes
5/6/2025	1st User for PH and EP-A for Alkalinity	7.8	25.5			Yes
5/7/2025	1st User for PH and EP-A for Alkalinity	7.8	25.6			Yes
5/8/2025	1st User for PH and EP-A for Alkalinity	7.8	25.5			Yes
5/9/2025	1st User for PH and EP-A for Alkalinity	7.8	26.0			Yes
5/10/2025	1st User for PH and EP-A for Alkalinity	7.8				Yes
5/11/2025	1st User for PH and EP-A for Alkalinity	7.8				Yes
5/12/2025	1st User for PH and EP-A for Alkalinity	7.8	26.8			Yes
5/13/2025	1st User for PH and EP-A for Alkalinity	7.8	26.6			Yes
5/14/2025	1st User for PH and EP-A for Alkalinity	7.8	26.0			Yes
5/15/2025	1st User for PH and EP-A for Alkalinity	7.8	26.0			Yes
5/16/2025	1st User for PH and EP-A for Alkalinity	7.8	26.7			Yes
5/17/2025	1st User for PH and EP-A for Alkalinity	7.8				Yes
5/18/2025	1st User for PH and EP-A for Alkalinity	7.8				Yes
5/19/2025	1st User for PH and EP-A for Alkalinity	7.8	25.8			Yes
5/20/2025	1st User for PH and EP-A for Alkalinity	7.8	25.8			Yes
5/21/2025	1st User for PH and EP-A for Alkalinity	7.8	25.4			Yes
5/22/2025	1st User for PH and EP-A for Alkalinity	7.8	25.8			Yes
5/23/2025	1st User for PH and EP-A for Alkalinity	7.7	26.0			Yes
5/24/2025	1st User for PH and EP-A for Alkalinity	7.7				Yes
5/25/2025	1st User for PH and EP-A for Alkalinity	7.7				Yes
5/26/2025	1st User for PH and EP-A for Alkalinity	7.7	26.2			Yes
5/27/2025	1st User for PH and EP-A for Alkalinity	7.7	26.1			Yes
5/28/2025	1st User for PH and EP-A for Alkalinity	7.7	26.8			Yes
5/29/2025	1st User for PH and EP-A for Alkalinity	7.7	25.8			Yes
5/30/2025	1st User for PH and EP-A for Alkalinity	7.7	26.4			Yes
5/31/2025	1st User for PH and EP-A for Alkalinity	7.7				Yes

Total number of excursions for PH during this monitoring period =

0

Total number of excursions for Alkalinity during this monitoring period =

0

Send to dwp.dmce@state.or.us within 10 days after end of sampling period

For OHA use only:

Minimum Water Quality


Parameters as set by: DHS

pH	7.2
Alk	23

Signature:

Print Name:

Date:



Troy N. Trute

6/6/2025